


Georgia Power Company
Post Office Box 4545
Atlanta, Georgia 30302
Telephone 404 522-6060

Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202
Telephone 205 870-6011

TIC
50-434
405

Vogtle Project

November 1, 1979

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, GA 30303

REFERENCE:
RII: JPG
50-424
50-425
File: X7BC24
Log: GM-518

Attn: Mr. James P. O'Reilly

Gentlemen:

The following is submitted in response to your letter dated September 27, 1979 concerning I.E. Bulletin 79-24.


No safety related piping systems have been installed at Plant Vogtle.

All piping and instrumentation diagrams for safety-related systems shall include a note regarding cold weather protection. This note shall state:

All Safety-related process, instrument, and sampling lines that are physically routed in an area exposed to extremely cold weather shall be provided with adequate heat tracing.

Additionally, cold weather protection will be specifically identified as an item to be reviewed during the regularly scheduled Physical Design Review Meeting.

Very truly yours,



Doug Dutton
Project General Manager

1373 195

CNH:tp

xc: U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, DC 20555

7911200 117

1190178
ORIGINAL COPY

Mr. James P. O'Reilly
RII: JPO, 50-424, 50-425
November 1, 1979
Page 2

xc: M. D. Hunt - USNRC, Region II

J. H. Miller, Jr.
W. E. Ehrensperger
F. G. Mitchell, Jr.
C. F. Whitmer
R. J. Kelly
R. E. Conway
R. W. Staffa
J. T. Beckham, Jr.
K. M. Gillespie
C. W. Hayes
E. D. Groover
D. L. McCrary
R. A. Thomas
M. Z. Jeric
J. L. Vota

1373 196