

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N | C | B | E | P | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5 |
7 8 9 14 15 25 26 30 37 CAT 38

0 1 7 8 REPORT SOURCE L 6 0 5 0 - 0 3 2 5 7 1 0 2 5 7 9 3 9 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0	2	While performing PT 9.2, HPCI Pump and Valve Operability Check, and PT 9.5, HPCI
---	---	--

0	3	1000# Flow Rate Test, torus water temperature reached 106°F, exceeding the allowed
---	---	--

0 4 | maximum value of 105°F. Torus cooling was in operation during most of this testing.

05

06

07 _____

08 Technical Specification 3.6.2. 6.9.1.9b

09		SYSTEM CODE S A		CAUSE CODE A		CAUSE SUBCODE A		COMPONENT CODE Z Z Z Z Z Z						COMP. SUBCODE Z		VALVE SUBCODE Z																	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22																		
LER/RO REPORT NUMBER		EVENT YEAR 7 9		SEQUENTIAL REPORT NO. 0 8 7		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0		ACTION TAKEN X		FUTURE ACTION G		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0				ATTACHMENT SUBMITTED Y		NPRD-4 FORM SUB. Y		PRIME COMP. SUPPLIER N		COMPONENT MANUFACTURER Z 9 9 9			
23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54		

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The high torus water temperature was caused by extended operation of the HPCI

11 turbine necessitated by a requirement to obtain bearing temperature data. The HPCI

1 2 | turbine was secured and the temperature was reduced to less than 95°F. Present

1 3 | procedures required torus cooling to be placed in operation at 95° F when surveil-

1 4 lance testing is in progress which adds heat to the torus. These procedures (cont'd)

8 9 FACILITY STATUS (28) 1 5 F 7 8 9

10 12 13 % POWER (29) 0 3 8 NA 44

OTHER STATUS (30)

45 46 METHOD OF DISCOVERY (31) B Periodic Test 80

DISCOVERY DESCRIPTION (32)

ACTIVITY CONTENT
RELEASED OF RELEASE

1	6
7	8

9

Z

(33)

10

Z

(34)

11

AMOUNT OF ACTIVITY (35)

NA

44

LOCATION OF RELEASE (36)

NA

45

80

PERSONNEL EXPOSURES			TYPE		DESCRIPTION
NUMBER					
1	7	0	0	0	(37) Z (38) NA

PERSONNEL INJURIES		NUMBER		DESCRIPTION		NA	
1	H	0	0	0	40		
7	8	9	11	12			

1367 140 80

LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION NA

PUBLICITY (45) NARC USE ONLY

ISSUED DESCRIPTION (44) NA

7 8 9 10 68 69 80

NAME OF PREPARER A. C. Tollison, Jr. 7911200 / PHONE: 919-457-9521

NAC USE ONLY

917-926

LER CONTINUATION -- RO# 1-79-87

Facility: BSEP Unit # 1

Event Date: 10-25-79

are being revised to require that torus cooling be placed in service when the torus water temperature reaches 90° F.