NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | ARANO1 (2) | 00-000-00 (3) | 4111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 05000313 (7) | 101779 (8) | 111679 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During routine Makeup Tank gas space sampling, a radioactive gas release
03 of approximately two times MPC (Maximum Permissible Concentration) over
04 a one hour period occurred, exceeding that allowable per E.T.S.2.4.2.3.a.
05 The stack monitor indication began to decrease immediately upon isolation
06 of the sample line. Sample time was no more than 10 minutes. No similar
07 occurrences. Reportable per E.T.S.5.6.2.b.
08

09 SYSTEM CODE PB (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE ZZZZZZ (14) | COMP SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 79 | — | SEQUENTIAL REPORT NO. 020 | / | OCCURRENCE CODE 04 | REPORT TYPE L | — | REVISION NO 0

ACTION TAKEN G (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB N (24) | PRIME COMP SUPPLIER Z (25) | COMPONENT MANUFACTURER Z999 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Radioactive gas sample activity in the Makeup Tank was higher than pre-
11 vious levels due to an apparent increase in failed fuel (<0.1% failed
12 fuel). Evaluation of Makeup Tank gas space is not required. Therefore,
13 sampling of the Makeup gas space has been temporarily discontinued. Pro-
14 cedures are being revised to allow sampling by a different technique.

15 FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Stack Monitor Alarm

16 ACTIVITY RELEASED G (33) | CONTENT OF RELEASE N (34) | AMOUNT OF ACTIVITY (35) 120 curies, predominately Xe-133 | LOCATION OF RELEASE (36) Rx Auxiliary Bldg. Vent to Atmosphere

17 PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

1391 294

18 PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

POOR ORIGINAL

19 LOSS OF OR DAMAGE TO FACILITY (43) TYPE Z (42) | DESCRIPTION NA

20 PUBLICITY ISSUED Y (44) | DESCRIPTION (45) Local & Area Newspaper & Radio Account | NRC USE ONLY

NAME OF PREPARER Chris N. Shively PHONE: 501/968-2519

7911260 365