

SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE BOX 764

COLUMBIA, SOUTH CAROLINA 29218

T.C. NICHOLS, JR.
VICE PRESIDENT AND GROUP EXECUTIVE
POWER PRODUCTION AND SYSTEM OPERATIONS

CGSV-03-0079-NO

October 19, 1979

Mr. R. C. Lewis
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W.
Suite 3100
Atlanta, Georgia 30303

Subject: RII:JLS
50-395/79-28


Dear Sir:

This refers to the Notice of Deviation as identified in Appendix A of Inspection Report No. 79-28. Corrective actions concerning this item are as follows:

- (1) Section 14.1.1.1 of the FSAR is being revised in upcoming Amendment 16 to state that the Plant Manager or his designated alternate will approve Phase II Preoperational Test Procedures.
- (2) The Plant Manager has issued a letter (CGSS-04-0296-NO), dated September 24, 1979, to the plant staff stating who may serve as his designated alternates.

Should you have any questions concerning this matter, please contact us.

Very truly yours,



T. C. Nichols, Jr.

ARK:nfb

cc: G. C. Meetze
M. C. Johnson
H. T. Babb
O. S. Bradham
A. A. Smith
M. B. Whitaker
NPCF
File (2)
J. Skolds

1399 343

7911270 037

790337
OFFICIAL COPY