



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

PRODUCTION DEPARTMENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street - Suite 3100
Atlanta, Georgia 30303

November 19, 1979

ATTENTION: Mr. J. P. O'Reilly

Dear Sir:

SUBJECT: Grand Gulf Nuclear Station
File 0270/15525/15526
Potential Reportable Deficiency
No. 79/04 - Interim Report No. 3
AECM-79/126


On February 23, 1979, Mississippi Power & Light Company notified Mr. W. B. Kenna of your office of a potential reportable deficiency at the Grand Gulf Nuclear Station construction site. The deficiency concerns inadequate crimping in certain Power Generation Control Complex (PGCC) interconnecting cable pen connections supplied by the General Electric Company.

G. E. has issued the following Field Disposition Instructions:

1. FDI-WAGM, Rev. 0; calls for 100% inspection of termination modules for damaged wire insulation.
2. FDI-WAGM, Rev. 2; calls for 100% inspection of G. E.-supplied PGCC cables and repair where required.

Inspection and repair work is presently being done on equipment at the site. We expect to submit the results of this activity to you in a final report by January 30, 1979.

Yours truly,


L. F. Dale
Nuclear Project Manager

7911270 473

JRF:pa

cc: Mr. T. B. Conner
Mr. R. B. McGehee

Mr. Victor Stello, Jr., Director
Division of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

bcc: Dr. D. C. Gibbs
Mr. A. Zaccaria
Mr. D. M. Lake
Mr. J. N. Ward
Mr. H. H. Weber
Mr. W. L. Nail
Mr. J. P. McGaughy
Mr. T. E. Reaves
Mr. C. K. McCoy
Mr. A. R. Smith

Member Middle South Utilities System File

S
Bo's, 10

1399 138