



November 2, 1979  
L-79-319

TIC  
50-389

NOV 9 10:21


Mr. James P. O'Reilly, Director, Region II  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
101 Marietta St., N. W., Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: RII:JPO  
50-389  
I & E Bulletin 79-14

Florida Power & Light Company has reviewed the issues presented in 79-14, Seismic Analyses For As-Built Safety-Related Piping Systems. St. Lucie Unit 2 has only recently begun installation of seismic Category I piping. The construction QC program will follow the progress of all such installation to ensure that all seismic Category I piping is installed in accordance with the drawings used for the seismic analyses.

Very truly yours,

  
Robert E. Uhrig  
Vice President  
Advanced Systems & Technology

REU/MV/ah

cc: T. E. Burdette  
Harold F. Reis, Esquire

1402 017

790146

7911280 315