


CONTROL BLOCK:  ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	A	L	B	R	F	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5																									
7	8	9							14							15							25							26							30							57							CAT		58	
		LICENSEE CODE														LICENSE NUMBER														LICENSE TYPE																								

CON'T

9	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	2	5	9	7	0	1	2	9	7	9	8	1	1	2	3	7	9	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

DOCKET NUMBER

EVENT DATE

REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operation while performing surveillance test SI 4.4.A.1, SLC pump 1B re-

0 3 | lief valve opened at 700 psig rather than the 1425 +/-75 psig specified by T.S.4.4.A.-

0 4 | 2.A. Previous occurrences: 50-296/7418, 50-296/778, 50-296/771, and 50-296/7713.

0 5 | There was no hazard to the public health or safety. The redundant pump was checked

0 6 | operable immediately.

0 7

0 8

1 8 0

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMP. SUBCODE		VALVE SUBCODE	
S	F	E	B	V	A	L	V	E	S
9	10	11	12	13	14	15	16	17	18
EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.	
7	9	0	0	2	0	3	L	1	1
21	22	23	24	25	26	27	28	29	30
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS	
A	Z	Z	Z	0	0	0	0	0	0
31	32	33	34	35	36	37	38	39	40
ATTACHMENT SUBMITT		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER		SUB.		N	
N	N	C	7	1	0	N	N	N	N
41	42	43	44	45	46	47	48	49	50

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Deterioration in the valve seating surface caused chattering which eventually induced  
1 1 premature opening of the JMWK pressure relief valve. The seats were pitted and cor-  
1 2 roded. The seating parts were replaced and the proper pressure relief setpoint veri-  
1 3 fied. To prevent recurrence, SI 4.4.A.1 was revised. Test pressure was lowered to  
1 4 1150 psig which resulted in less valve chatter while throttling.

8 9  
FACILITY STATUS % POWER OTHER STATUS (30)  
1 5 E (28) 0 6 0 (29) NA 44  
7 8 9 10 11 12 13  
45  
METHOD OF DISCOVERY (31) DISCOVERY DESCRIPTION (32)  
B (31) Surveillance testing 80  
46  
ACTIVITY CONTENT  
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)  
1 6 Z (33) Z (34) NA 44  
7 8 9 10 11 12 13  
45  
LOCATION OF RELEASE (36)  
NA 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	(39)

PERSONNEL INJURIES		NUMBER		DESCRIPTION (41)	
1	8	0	0	0	(40) NA

7 8 9 11 12 80

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE DESCRIPTION

17 1 NA

1	9	Z	(42)	NA
7	8	9	10	80

ISSUED (44) DESCRIPTION (45) NA 7912040 303

NAME OF PREPARER \_\_\_\_\_

PHONE: 1472 036