NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	Licensee Code (2)	VANAS1
01	License Number (3)	00-00000-00
01	License Type (4)	41111
01	CAT (5)	
01 CON'T	Report Source (6)	L
01	Docket Number (7)	05000338
01	Event Date (8)	110179
01	Report Date (9)	112879

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On November 1, 1979, with the unit in a refueling shutdown, it was discovered that
03 the required weekly surveillance of the DC Distribution System including the station
04 batteries, emergency diesel generator batteries, and diesel fire pump batteries, had
05 not been performed for the previous four consecutive weeks. Since the periodic test
06 was immediately performed and all batteries were found satisfactory, the health and
07 safety of the general public were not affected. Reportable pursuant to T.S. 6.9.1.9.c.
08

Line	System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
09	EC	A	C	BATTRY	Z	Z

(17) LER/RO REPORT NUMBER

Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
79	—	150	/	03	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
X	H	Z	Z	0000	Y	N	A	X999

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The periodic test was not performed because of a loss of administrative control. The
11 individual responsible for assigning work was under the impression that the test was
12 not required during refueling. The DC Distribution System was immediately tested and
13 the individual involved was made aware of his mistake.
14

Line	Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
15	H	000	NA	C	Reviewed by Cognizant Supervisor

Line	Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
16	Z	Z	NA	NA

PERSONNEL EXPOSURES

Line	Number (37)	Type (38)	Description (39)
17	000	Z	NA

PERSONNEL INJURIES

Line	Number (40)	Description (41)
18	000	NA

LOSS OF OR DAMAGE TO FACILITY (43)

Line	Type (42)	Description
19	Z	NA

1473 180

7912040316

PUBLICITY

Line	Issued (44)	Description (45)	NRC USE ONLY
20	N	NA	

NAME OF PREPARER W. R. Cartwright PHONE: 703-894-5151

Virginia Electric and Power Company
North Anna Power Station, Unit #1
Docket No. 50-338
Report No. LER 79-150/03L-0

Description of Event

On November 1, 1979, with the unit in Mode 6, it was discovered that the required weekly surveillance of the DC Distribution System, which includes the station batteries, emergency diesel generator batteries, and diesel fire pump batteries, had not been performed for the previous 4 consecutive weeks.

Probable Consequences of Occurrence

The consequences of this event were minimal because the DC Distribution System was immediately tested and all batteries were found to be acceptable. As a result, the health and safety of the general public were not affected. There are no generic implications associated with this event.

Cause of Occurrence

The periodic surveillance of the DC Distribution System was missed because of a loss of administrative control. The individual responsible for assigning work in the Electrical Department was under the impression that the periodic test was not required during refueling.

Immediate Corrective Action

The periodic test for the DC Distribution System was immediately performed and the individual concerned was made aware that the tests will be accomplished in a timely manner regardless of plant mode of operation.

Scheduled Corrective Action

No scheduled corrective action is required.

Actions Taken to Prevent Recurrence

No further actions are required.

Other Information

Component Manufacturer required by block 26:

C173
E355
Willard