

November 29, 1979

BECo Ltr. #79-255

Director
Office of Management Information and Program Control
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Docket Number 50-293
License DPR-35

Subject: REVISED October, 1979 Monthly Report

Dear Sir:

In accordance with PNPS Technical Specification 6.9.A.2, a copy of the revision to the Operational Status Summary for Pilgrim Nuclear Power Station is attached for your information and planning.

This revision changes line 23 of the "Operating Data Report" and also indicates the scheduled shutdown for refuel in 1980. The revision to line 23 is detailed on the "Unit Shutdowns and Power Reductions" Report Numbers 15 and 16.

Respectfully Submitted,

P. J. McGuire
Station Manager
Nuclear Operations

GGW:ep

cc: Director ✓
Office of Inspection and Enforcement
Office of Nuclear Regulatory Commission
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Director of Region I
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

1502 235

A008

3
1/1

R 7912050

448

POOR ORIGINAL

OPERATING DATA REPORT

DOCKET NO. 50-293
DATE 11/17/79
COMPLETED BY G.G. Whitney
TELEPHONE 617-746-7900

OPERATING STATUS

1. Unit Name: Pilgrim I
2. Reporting Period: October, 1979
3. Licensed Thermal Power (MWT): 1998.
4. Nameplate Rating (Gross MWe): 678.
5. Design Electrical Rating (Net MWe): 655.
6. Maximum Dependable Capacity (Gross MWe): 690.
7. Maximum Dependable Capacity (Net MWe): 670.
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:
NONE

Notes

9. Power Level To Which Restricted, If Any (Net MWe): NONE
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours in Reporting Period	745.0	7296.0	60422.0
12. Number Of Hours Reactor Was Critical	727.9	6469.2	43516.9
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator On-Line	720.2	6365.9	42088.5
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Thermal Energy Generated (MWH)	1260768.0	11843304.0	70285104.0
17. Gross Electrical Energy Generated (MWH)	434510.0	4065840.0	23196314.0
18. Net Electrical Energy Generated (MWH)	418758.0	3913648.0	22275212.0
19. Unit Service Factor	96.7	87.3	69.6
20. Unit Availability Factor	96.7	87.3	69.6
21. Unit Capacity Factor (Using MDC Net)	83.9	80.1	55.0
22. Unit Capacity Factor (Using DER Net)	85.8	81.9	56.3
23. Unit Forced Outage Rate	3.3	12.3	11.0

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
Refuel Outage, commencing January 5, 1980 to April 7, 1980.

25. If Shut Down At End Of Report Period, Estimated Date of Startup: UNIT OPERATING
26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

1502 236

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

7912060375

[Handwritten signature]
7912060375
(177)

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH OCTOBER, 1979DECKET NO. 50-293UNIT NAME Pilgrim IDATE 11/1/79COMPLETED BY G.G. WhitneyTELEPHONE 617-746-7900

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
14	08/28/79	F	0.0	B	3	79-33/1X-0	CZ	ZZZZZZ	During Recovery from loss of off-site power event, B Condensate Pump failed. Repairs to Pump and Motor continue.
15	10/15/79	F	13.0	H	3				Low Suction Pressure to Feed Pumps Caused "C" RFP to Trip resulting in low water scram.
16	10/25/79	F	11.8	H	3				Inadvertent mechanical shock applied during surveillance.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance of Test
C Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

5
Exhibit I - Same Source

(9/77)

1502 237

POOR ORIGINAL