

CONTROL BLOCK: 1 1 1 1 1 1 6 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 G A E I H 1 2 0 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5

7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON

0	1
---	---

7 8

REPIST SOURCE

L	6	0	5	0	0	0	3	2	1	7	1	1	1	2	7	9	8	1	1	2	7	7	9	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | During normal operations the monthly functional tests on the Unit 1 and Unit 2 Liquid

03 | Radwaste Radiation Monitors were not performed as required by Environmental Tech Specs

04 | section 2.1.2.f. There was no significant occurrence that took place as a result of

05 | this event. There were no probable consequences as a result of this event. There was

06 | no release of radioactive material as a result of this occurrence and no effect on the

07 | public health and safety. This is not a repetitive event.

[illegible]

1 0 | A Chemical Radiation Technician training class was in progress during the scheduled
1 1 | functional test time period for these monitors. Technicians who were not in class
1 2 | were scheduled to work overtime in order to complete Tech Spec analysis requirements.
1 3 | Insufficient time, however, was allotted for the completion of these functional tests
1 4 | within the allowed time frame. The functional tests were completed on 11-12-79, (cont)

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	28	0	9	9	29	N/A	B
7	8	9	10	12	13	44	45	46	80
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	33	Z	34	N/A	N/A	36	
7	8	9	10	11	12	44	45		80
PERSONNEL EXPOSURES		NUMBER		DESCRIPTION					
1	7	0	0	0	37	Z	38	N/A	
7	8	9	11	12	13				80
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
1	8	0	0	0	40			N/A	1497 309
7	8	9	11	12					80
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	Z	42			N/A		7912050	457
7	8	9	10						80
PUBLCITY		ISSUED		DESCRIPTION				NRC USE ONLY	
2	0	N	44			N/A			
7	8	9	10						80

PHONE: 912-367-7781

Georgia Power Company
Plant E. I. Hatch
Baxley, Georgia 31513

Reportable Occurrence Report Number 50-321/1979-093

Cause Description and Corrective Actions

one day past due. In the future, more time will be scheduled to complete these tests.

1497 510