

LICENSEE EVENT REPORT

CONTROL BLOCK: ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 N C B E P 1 ② 0 0 - 0 0 0 0 0 - 0 0 ③ 4 1 1 1 1 ④ ⑤
R 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 58

1 REPORT SOURCE L ⑥ 0 5 0 - 0 3 2 5 ⑦ 1 1 0 1 7 9 ⑧ ⑨
8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

2 During normal plant operation, the auxiliary operator, on a tour of the Reactor Build-
3 ing, noticed that the RHR flow indicator 1E11-FI-3338, on the Remote Shutdown Panel,
4 was indicating 2500 gpm with the system not in operation.

Technical Specification 3.3.5.2, 6.9.1.9b

SYSTEM CODE C F ⑪ CAUSE CODE E ⑫ CAUSE SUBCODE G ⑬ COMPONENT CODE I N S T R U ⑭ COMP. SUBCODE I ⑮ VALVE SUBCODE Z ⑯
17 LER/RO REPORT NUMBER 7 9 ⑰ EVENT YEAR 21 22 SEQUENTIAL REPORT NO. 0 8 4 ⑱ OCCURRENCE CODE 0 3 ⑲ REPORT TYPE L ⑳ REVISION NO. 0 ㉑
ACTION TAKEN E ⑳ FUTURE ACTION Z ㉑ EFFECT ON PLANT Z ㉒ SHUTDOWN METHOD Z ㉓ HOURS 0 0 0 ㉔ ATTACHMENT SUBMITTED N ㉕ NPRD-4 FORM SUB. Y ㉖ PRIME COMP. SUPPLIER A ㉗ COMPONENT MANUFACTURER I 1 3 0 ㉘
33 34 35 36 37 40 41 42 43 44 47

C/USE DESCRIPTION AND CORRECTIVE ACTIONS ㉚

5 The indicator FI 3338 and the transmitter FI 3338 were calibrated and the system was
6 returned to service. This instrument is calibrated on a quarterly schedule. This is
7 considered an isolated event and no further action is required.

8 FACILITY STATUS 1 ㉙ % POWER 1 0 0 ㉚ OTHER STATUS N/A ㉛ METHOD OF DISCOVERY A ㉜ DISCOVERY DESCRIPTION Operator Surveillance ㉝
9 10 11 12 13 44 45 46 80
ACTIVITY CONTENT 2 ㉞ RELEASED OF RELEASE 2 ㉟ AMOUNT OF ACTIVITY N/A ㊱ LOCATION OF RELEASE ㊲
9 10 11 12 13 44 45 80

PERSONNEL EXPOSURES
NUMBER 0 0 0 ㊲ TYPE Z ㊳ DESCRIPTION N/A ㊴
9 10 11 12 13 44 45 80

PERSONNEL INJURIES
NUMBER 0 0 0 ㊴ DESCRIPTION N/A ㊵
9 10 11 12 13 44 45 80

LOSS OF OR DAMAGE TO FACILITY
TYPE Z ㊵ DESCRIPTION N/A ㊶
9 10 11 12 13 44 45 80

PUBLICITY
ISSUED N ㊶ DESCRIPTION N/A ㊷
9 10 11 12 13 44 45 80

NRC USE ONLY

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919 - 457-9521

1494 002

7912050

480