

UPDATE REPORT

Previous Report Date 8/31/79

NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 AR AN 01 00 -0 00 00 -0 00 41 11 11 11 4 5

LICENSEE CODE 14 LICENSE NUMBER 25 LICENSE TYPE 30 CAT 56

CON'T

01 L 05 00 03 13 7 08 10 79 8 12 06 79 9

REPORT SOURCE 60 DOCKET NUMBER 68 EVENT DATE 74 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 With the unit in a Cold Shutdown Condition, Leak Rate Testing of the

03 Reactor Building Purge valves at penetration V-1 indicated a leak rate

04 in excess of 50,000 cc/minute, exceeding that allowed per T.S.4.4.1.2.3.

05 The excessive leakage was determined to be due to the outside isolation

06 valve, CV-7402. The inside isolation valve, CV-7404, test results were

07 within acceptable limits. This occurrence is similar to LER's 50-313/

08 79-005 & 77-015. Reportable per T.S. 6.12.3.2.b.

SYSTEM CODE 1 CAUSE CODE E CAUSE SUBCODE B COMPONENT CODE V VALVE SUBCODE E VALVE SURCODE D

LER/NO REPORT NUMBER 79 EVENT YEAR 79 SEQUENTIAL REPORT NO. 012 OCCURRENCE CODE 03 REPORT TYPE X REVISION NO. 1

ACTION TAKEN E FUTURE ACTION Z EFFECT ON PLANT Z SHUTDOWN METHOD Z HOURS 00000 ATTACHMENT SUBMITTED N NRC/D-4 FORM SUB Y PRIME COMP SUPPLIER A COMPONENT MANUFACTURER P

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 Investigation revealed that the valve required an adjustment of the valve

11 seat shims to match the butterfly with the seating surface. The leak

12 rate was verified to meet the 60% LA requirement after adjustment. The

13 testing frequency was modified for testing prior to heatup if operated

14 since last leak rate test, not to exceed 18 months. Valve operation is

15 limited to cold shutdown condition (RCS < 200°F).

FACILITY STATUS D % POWER 000 OTHER STATUS 30 METHOD OF DISCOVERY B DISCOVERY DESCRIPTION 32

ACTIVITY CONTENT D RELEASED OF RELEASE Z AMOUNT OF ACTIVITY NA LOCATION OF RELEASE NA

PERSONNEL EXPOSURES NUMBER 000 TYPE Z DESCRIPTION NA

PERSONNEL INJURIES NUMBER 000 DESCRIPTION NA

LOSS OF OR DAMAGE TO FACILITY TYPE Z DESCRIPTION NA

PUBLICITY ISSUED N DESCRIPTION NA

NAME OF PREPARER Chris N. Shively PHONE 501/968-2519

1591 243

7912170269