

## (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	C	Q	F	S	V	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	2	0	4			5
7	8	LICENSEE CODE						14	LICENSE NUMBER										25	LICENSE TYPE						30	57 CAT 58		

REPORT SOURCE 7 8 60 61 68 69 74 75 80

DOCKET NUMBER 0 5 0 0 0 2 6 7 7 1 0 2 9 7 9 8 1 2 1 0 7 9 9

EVENT DATE

REPORT DATE

0	2	Standby diesel engine 1B tripped on high cooling water temperature during surveillance
---	---	--

03 | test because cooling water valves were lined up incorrectly. Reportable per Fort St.

0	4	Vrain Technical Specification AC 7.5.2(b)3. No accompanying occurrence. Cooler
---	---	--

05 | isolated, bypass not opened. No affect on public health or safety. Redundant diesel

06 | engine available and operable.

0	7	
---	---	--

0	8	
---	---	--

0 9  
 7 8

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE  
 W A 11 A 12 B 13 V A L V E X 14 E 15 D 16  
 9 10 11 12 13 14 15 16 17 18 19 20

(17) LER/RO REPORT NUMBER	EVENT YEAR 7 9	REPORT NO. 0 5 4	CODE 0 3	TYPE X	NO. 1
ACTION TAKEN X 18 Z 19	FUTURE ACTION	EFFECT ON PLANT Z 20	SHUTDOWN METHOD Z 21	HOURS 0 0 0 0	ATTACHMENT SUBMITTED Y 23
				NPRD-4 FORM SUB. N 24	PRIME COMP. SUPPLIER Z 25
					COMPONENT MANUFACTURER Z 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	Standby diesel engine 1B cooler isolated to repair cooling water tube leak. Clear-
---	---	--

11 | lance point form specified opening cooler bypass valve. Valve was not opened as re-

1 2 | quired. Operator reinstructed. Cooling water restored. Surveillance test com-

13 | pleted.

1	4
---	---

1 5 FACILITY STATUS G 28 % POWER 0 0 0 29 OTHER STATUS 30 N/A METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION 32 Surveillance Test

ACTIVITY CONTENT  
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z (33) Z (34) N/A N/A

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0 0 0	(37) Z	(38) N/A (39)					

PERSONNEL INJURIES		DESCRIPTION (41)		1607 358	
NUMBER					
1	8	0	0	0	(40) N/A

		8		9		11		12		
		LOSS OF OR DAMAGE TO FACILITY		(43)						
		TYPE		DESCRIPTION						
1	9	Z	(42)	N/A						
		7912180610								

7 8 9 10 80

PUBLICITY

ISSUED N (44) DESCRIPTION (45) N/A

NRC USE ONLY

NAME OF PREPARER

J. W. Gahm

PHONE:

(303) 785-2253