



ARKANSAS POWER & LIGHT COMPANY  
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

January 9, 1980

1-010-14  
2-010-12

Mr. Walter P. Haass, Chief  
Quality Assurance Branch  
Division of Project Management  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Subject: Arkansas Nuclear One - Units 1 & 2  
Docket Nos. 50-313 and 50-368  
License Nos. DPR-51 and NPF-6  
Quality Assurance Program  
TOPICAL Report (APL-TOP-1A Rev. 5)  
(File: 1510.1, 2-1510.1, 0233.1)

Reference: 1) Letter W.P. Haass to D. Trimble  
dated 12/5/79 regarding  
APL-TOP-1A Rev. 5

Dear Mr. Haass:

Enclosed are twenty-five copies of affected page changes to APL-TOP-1A Rev. 5 as requested. The staff positions forwarded by the referenced letter have been addressed. Attachment 1 provides a cross reference between the staff positions of reference 1 and the page number where the revised response is contained. As discussed with your Mr. Conway on 12/18/79, additional changes have been made as follows:

- A. The previous position of QC Supervisor has been changed to Manager of Nuclear Quality Control. This change has been reflected throughout the manual.
- B. Typographical errors have been corrected where detected. This includes changing Executive Director-G&C to Vice President-G&C in those paragraphs which were not updated during our June 11, 1979 submittal.
- C. Appendix A, page 13, has been changed to show that the Pre-construction Verification interpretation applies to ANSI N45.2.8 in addition to ANSI N45.2.4 which was previously listed.

8001170375

- D. Paragraph 4.2.2(4) has been changed to better align with ANSI N45.2.13 and the reference to ANO-19, which was previously in paragraph 4.2.2(4), is now in 4.2.2(1).
- E. The last three sentences of paragraph 7.2.1 of Section 7 have been deleted as this information is redundant to that of Appendix A, page 29, item 3.

In our 6/11/79 submittal to you, we discussed the possibility that ANO implementing procedure titles and numbering could be changing. We have concluded that these changes are necessary in order to effectively implement the requirements of APL-TOP-1A revision 5. These changes will be included in a future revision of the TOPICAL.

Sincerely,

*David C. Trimble*

David C. Trimble  
Manager, Licensing

DCT:pw

Attachment

cc: Messrs.	D. A. Rueter	Without/att.
	D. R. Sikes	Without/att.
	J. M. Griffin	Without/att.
	J. P. O'Hanlon	Without/att.
	B. L. Bata	Without/att.

ATTACHMENT 1

STAFF POSITION

PAGE/PARAGRAPH CONTAINING RESPONSE

421.62	Section 5, Page 2, Paragraph 5.2.6
421.63	Appendix A - Page 1, Item 3
421.64	Appendix A - Page 3, Item 1
421.65	Appendix A - Page 15. Our exception to section 4.6 of ANSI N45.2.5 has been deleted. Finishes will be inspected.
421.66	Appendix A - Page 17. Our exception to section 5.1 of ANSI N45.2.5 has been deleted. When grouting is performed, in process testing of the grout on a daily basis will be performed.
421.67	Appendix A - Page 18. Our exception to section 5.2 of ANSI N45.2.5 has been deleted. The composite of each shipment will be tested for chemical composition, pH, and specific gravity in accordance with ASTM C-494.
421.68	Per the telecon between our L. Humphrey and your J. Conway on 12/18/79, no response is necessary. We presently do not have a position of QA Supervisor (Nuclear), nor does the QA organization chart show the position. We wish to have the general information in paragraph 1.4.1.1.2.1 and 1.4.1.1.2.3 in case a Quality Assurance Supervisor (Nuclear) is added in the future.

TABLE OF CONTENTS  
ARKANSAS POWER & LIGHT COMPANY

<u>SECTION</u>	<u>SUBJECT</u>	<u>TAB</u>	<u>PAGE</u>
	<u>POLICY STATEMENT</u>		
	<u>FORWARD</u>		
	<u>TERMS AND DEFINITIONS</u>		
1.	<u>ORGANIZATION</u>	1	1
1.1	<u>SCOPE</u>		1
1.2	<u>ARKANSAS POWER &amp; LIGHT COMPANY</u>		1
1.3	<u>SUPPORTIVE SERVICES</u>		1
1.3.1	<u>MANAGER OF SAFETY</u>		1
1.3.2	<u>SUPERVISOR OF PURCHASING</u>		1
1.4	<u>GENERATION AND CONSTRUCTION</u>		2
1.4.1	<u>DIRECTOR, TECHNICAL &amp; ENVIRONMENTAL SERVICES</u>		2
1.4.1.1	<u>QUALITY ASSURANCE ORGANIZATION (QAO)</u>		3
1.4.2	<u>DIRECTOR, PROJECTS MANAGEMENT</u>		6
1.4.3	<u>DIRECTOR, GENERATION OPERATIONS</u>		6
1.4.4	<u>DIRECTOR, GENERATION ENGINEERING</u>		7
1.4.5	<u>DIRECTOR, ADMINISTRATIVE SERVICES &amp; PROJECT SUPPORT</u>		7
1.5	<u>ARKANSAS NUCLEAR ONE ORGANIZATION</u>		8
1.5.1	<u>GENERAL MANAGER</u>		8
1.5.2	<u>OPERATIONS &amp; MAINTENANCE MANAGER</u>		8
1.5.3	<u>ENGINEER &amp; TECHNICAL SUPPORT MANAGER</u>		10
1.5.4	<u>PLANT ADMINISTRATION MANAGER</u>		12
1.5.5	<u>MANAGER OF NUCLEAR QUALITY CONTROL</u>		12
1.6	<u>QUALITY PROGRAM COMMITTEES</u>		13
1.6.1	<u>SAFETY REVIEW COMMITTEE</u>		13
1.6.2	<u>PLANT SAFETY COMMITTEE</u>		16
1.7	<u>ORGANIZATIONAL INTERFACES AND RESPONSIBILITIES</u>		18
2.	<u>QUALITY ASSURANCE PROGRAM</u>	2	1
2.1	<u>SCOPE</u>		1
2.2	<u>PURPOSE</u>		1
2.3	<u>APPLICABILITY</u>		1
2.4	<u>PROCEDURES</u>		3
2.5	<u>PROGRAM REVISION AND CONTROL</u>		4
2.6	<u>SYSTEM STRUCTURE AND COMPOSITION</u>		
2.7	<u>TRAINING AND PERSONNEL</u>		
2.8	<u>PROGRAM REVIEW</u>		

1762 238

DUPLICATE DOCUMENT

Entire document previously  
entered into system under:

ANO 7906190245  
No. of pages: 46



QUALITY ASSURANCE MANUAL  
TITLE: TABLE OF CONTENT