



Jersey Central Power & Light Company
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960
(201) 455-8200

June 26, 1979

Director
Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Fire Protection - Alternate Water Supply

By letter dated October 3, 1977, we submitted attachment 5 to the Oyster Creek Fire Protection Program - Comparison to Standard Review Plan 9.5.1. In this submittal we committed to provide an alternate means of supplying water to the yard loop in accordance with NRC Staff Position No. 7. Our commitment was to install either a tank and associated pump or a redundant supply line from our existing system based on the results of an engineering evaluation of these two alternatives.

The purpose for this correspondence is to inform you that the decision has been made to provide a tank of 300,000 gallon capacity as well as a pump of sufficient size to provide the fire protection system water demand. This system will connect to the existing yard loop.

This system will be scheduled for installation in accordance with Table 3.1 of the NRC Safety Evaluation Report on the Oyster Creek Fire Protection Program as required by paragraph 3.E of our Operating License No. DPR-16.

Very truly yours.

Ivan R. Finfrock, Jr.
Ivan R. Finfrock, Jr.
Vice President

268 096

7907020 180 F

ATTACHMENT NOT FILMED

ANO. 790702015

NO. OF PAGES _____

☐ DUPLICATE: ALREADY ENTERED INTO SYSTEM
UNDER ANO. _____

☐ ILLEGIBLE: HARD COPY AT:

☐ PDR

☐ CF

☐ OTHER _____

268 097