

OPERATING DATA REPORT

DOCKET NO. 50-267

DATE 790701

COMPLETED BY J. W. Gahm

TELEPHONE (303) 785-2253

OPERATING STATUS

NOTES

1. Unit Name: Fort St. Vrain, Unit No. 1
2. Reporting Period: 790601 to 790630
3. Licensed Thermal Power (MWt): 842
4. Nameplate Rating (Gross MWe): 342
5. Design Electrical Rating (Net MWe): 330
6. Maximum Dependable Capacity (Gross MWe): 342
7. Maximum Dependable Capacity (Net MWe): 330

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

None

9. Power Level To Which Restricted, If Any (Net MWe): 231

10. Reasons for Restrictions, If Any: Nuclear Regulatory Commission restriction (70%) pending resolution of certain Final Safety Analysis Report and Technical Specification bases discrepancies. This unit is in the power ascension phase of startup testing.

	This Month	Year to Date	Cumulative
11. Hours in Reporting Period	<u>720</u>	<u>4343</u>	<u>-----</u>
12. Number of Hours Reactor Was Critical	<u>328.7</u>	<u>1146.4</u>	<u>14620.1</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
14. Hours Generator On-Line	<u>0.0</u>	<u>665.3</u>	<u>8,507.9</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
16. Gross Thermal Energy Generated (MWH)	<u>2653</u>	<u>315,745</u>	<u>3,518,743</u>
17. Gross Electrical Energy Generated (MWH)	<u>0</u>	<u>109,852</u>	<u>1,058,122</u>
18. Net Electrical Energy Generated (MWH)	<u>0</u>	<u>101,177</u>	<u>952,628</u>
19. Unit Service Factor	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
20. Unit Availability Factor	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
21. Unit Capacity Factor (Using MDC Net)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
22. Unit Capacity Factor (Using DER Net)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
23. Unit Forced Outage Rate	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): Maintenance

Shutdown, October 20, 1979, 30 days

25. If Shut Down at End of Report Period, Estimated Date of Startup: N/A

7907120106

26. Units in Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

Forecast

Achieved

740201

740131

7612

761211

R

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-267
 UNIT NAME Fort St. Vrain, Unit No. 1
 DATE 790701
 COMPLETED BY J. W. Gahm
 TELEPHONE (303) 785-2253

REPORT MONTH June, 1979

NO.	DATE	TYPE	DURATION	REASON	METHOD OF SHUTTING DOWN REACTOR	LER #	SYSTEM CODE	COMPONENT CODE	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
79-04	790201	F	720	A	4	79-03/03-L-0	HH	PUMPXX	Excessive gland leakage on "B" boiler feed pump concurrent with inoperable "C" boiler feed pump necessitated controlled reactor shutdown on February 1, 1979, per LCO 4.3.2. Scheduled reactor shutdown for refueling was changed from March 1, 1979 to February 1, 1979. Thus shutdown number 79-04 has extended through February, March, April, May, and June, 1979. Although the reactor was critical for 328.7 hours in the reporting period, the turbine-generator remained off-line.

SUMMARY: Plant at less than 2% rated power to allow cleanup of secondary coolant chemistry.

354 220

AVERAGE DAILY UNIT POWER LEVEL

Docket No. 50-267

Unit Fort St. Vrain, Unit No. 1

Date 790701

Completed By J. W. Gahm

Telephone (303) 785-2253

Month June, 1979

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>0</u>
2	<u>0</u>
3	<u>0</u>
4	<u>0</u>
5	<u>0</u>
6	<u>0</u>
7	<u>0</u>
8	<u>0</u>
9	<u>0</u>
10	<u>0</u>
11	<u>0</u>
12	<u>0</u>
13	<u>0</u>
14	<u>0</u>
15	<u>0</u>
16	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>0</u>
18	<u>0</u>
19	<u>0</u>
20	<u>0</u>
21	<u>0</u>
22	<u>0</u>
23	<u>0</u>
24	<u>0</u>
25	<u>0</u>
26	<u>0</u>
27	<u>0</u>
28	<u>0</u>
29	<u>0</u>
30	<u>0</u>
31	<u>N/A</u>

*Generator on line but no net generation.

REFUELING INFORMATION

1. Name of Facility.	Fort St. Vrain, Unit No. 1
2. Scheduled date for next refueling shutdown.	September 1, 1980
3. Scheduled date for restart following refueling.	November 1, 1980
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?	No
If answer is yes, what, in general, will these be?	
If answer is no, has the reload fuel design and core configuration been reviewed by your Plant Safety Review Committee to determine whether any unreviewed safety questions are associated with the core reload (Reference 10CFR Section 50.59)?	The Plant Operations Review Committee will review any questions associated with the core reload
If no such review has taken place, when is it scheduled?	March 1, 1980
5. Scheduled date(s) for submitting proposed licensing action and supporting information.	-----
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.	-----
7. The number of fuel assemblies (a) in the core and (b) in the spent fuel storage pool.	a) 1482 HTGR fuel elements. b) 245 spent HTGR fuel elements.
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies.	Capacity is limited in size to about one third of core (approximately 500 HTGR elements). No change is planned.

REFUELING INFORMATION (CONTINUED)

9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity.	1986 under the Three Party Agreement (Contract AT (04-3)-633) between DOE, Public Service Company of Colorado (PSCo), and General Atomic Company.*
---	--

*The 1986 data is based on the understanding that spent fuel discharged during the term of the Three Party Agreement will be shipped to the Idaho National Engineering Laboratory for storage by DOE at the Idaho Chemical Processing Plant (ICPP). The storage capacity has evidently been sized to accommodate fuel which is expected to be discharged during the eight year period covered by the Three Party Agreement.