

LICENSEE EVENT REPORT

CONTROL BLOCK

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 C O F S V 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 2 0 4 5
7 8 9 14 15 25 26 30 37 CAT 38

CONT

01 REPORT SOURCE L 6 0 5 0 0 0 2 6 7 7 0 4 1 2 7 9 8 0 7 0 3 7 9 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During functional test of hydraulic shock suppressors (snubbers) many were found to
03 be inoperable. The snubbers had not been tested since installation and must be
04 assumed to have been inoperable while the reactor was at power contrary to LCO 4.3.10.
05 Snubbers were found to be inoperable due to unacceptable lockup and/or unacceptable
06 bleed characteristics. Reportable per Fort St. Vrain Technical Specification, Section
07 AC 7.5.2(b)2. There was no effect on public health and safety.

08
7 8 9 90

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
Z Z 11 E 12 B 13 S P O R T 14 D 15 Z 16
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
7 9 1 1 3 0 3 L 0
21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
D 18 Z 19 Z 20 Z 21 0 0 0 Y 22 N 23 A 25 I 2 0 7 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The cause of the failure of the snubbers to have acceptable lockup and bleed charac-
11 teristics was setpoint drift, dirty oil, and clogged valves. These snubbers are ITT-
12 Grinnel snubbers of various sizes and models. All snubbers tested were repaired/re-
13 adjusted prior to reinstallation.

14
7 8 9 80

15 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32
H 28 0 0 0 29 N/A B 31 Surveillance Test Results
7 8 9 10 12 13 44 45 46 80

16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
Z 33 Z 34 N/A N/A
7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
0 0 0 37 Z 38 N/A
7 8 9 10 11 12 13 80

18 PERSONNEL INJURIES NUMBER DESCRIPTION 41
0 0 0 40 N/A
7 8 9 10 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43
Z 42 N/A
7 8 9 10 80

20 PUBLICITY ISSUED DESCRIPTION 45
N 44 N/A
7 8 9 10 80

NAME OF PREPARER

J. W. Gahm

PHONE

(303) 785-2253

NRC USE ONLY

NRC 365-1-92-0