

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	E	C	P	R	1	2	0	0	-	0	0	0	0	-	0	2	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

CON'T

7 8 60 61 68 69 74 75 80

REPORT SOURCE L 6 0 5 0 0 0 2 9 8 7 0 5 0 9 7 9 8 0 6 0 8 7 9 9

DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | The reference chamber vent valve for torus level transmitter (PC-LT-12) was left
0 3 | closed after performing a special check verifying HPCI-LS-91B upper shutoff valve
0 4 | was open and free of obstruction. Torus water level was normal at all times and the
0 5 | redundant level indicator was available and operable. There was no effect upon
0 6 | public health and safety.
0 7 |
0 8 |

0 9		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE			
7	8	S	A	A	C	V	A	L	V	E	X	F	L				
17		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
LER/RO REPORT NUMBER		7	9	0 1 4		0 3		L		0							
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
H	Z	Z		Z		0 0 0 0		N		NPRD-4 FORM SUB.		L		D 2 3 2			
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | A technician failed to open the reference chamber vent valve for torus PC-LT-12 after
1 1 | completion of a special test. The reference chamber vent valve was opened and PC-LT-12
1 2 | placed back into service. This occurrence has been discussed with the personnel in-
1 3 | volved and a copy of the NCR has been routed to all Instrument Technicians.
1 4 |

FACILITY STATUS				% POWER				OTHER STATUS				METHOD OF DISCOVERY				DISCOVERY DESCRIPTION			
1	5	E	28	0	5	0	29	NA				A	31	Operator Observation					
ACTIVITY CONTENT				AMOUNT OF ACTIVITY				LOCATION OF RELEASE											
1	6	Z	33	Z	34	NA				NA									
PERSONNEL EXPOSURES				DESCRIPTION															
1	7	0	0	0	37	Z	38	NA											
PERSONNEL INJURIES				DESCRIPTION															
1	8	0	0	0	40	NA													
LOSS OF OR DAMAGE TO FACILITY				DESCRIPTION								7907170082							
1	9	Z	42	NA															
PUBLICITY				DESCRIPTION															
2	0	N	44	NA				353 047				NRC USE ONLY							

NAME OF PREPARER L. I. Lawrence

PHONE: 402-825-3811

NRC USE ONLY

353 047

917-926