

## LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 7 8 G A E T H 2 14 2 15 0 0 - 0 0 0 0 0 0 0 0 25 3 26 4 1 1 1 1 1 30 4 57 CAT 58 5

LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T

0 1 7 8 REPORT SOURCE L 6 60 0 5 61 0 0 0 3 6 6 63 7 69 0 1 6 2 0 1 7 9 74 8 75 0 7 1 0 7 9 80

DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 With RCIC Operating in the Steam Condensing Mode, RCIC Exhaust and RHR Heat Exchanger

0 3 vents to the torus increased the torus water level to 150.9 inches. Tech Specs.

0 4 3.6.2.1.a requires the water level to be between 146 inches and 150 inches. There was

0 5 no damage to the torus and no effect upon Public Safety or Health.

0 6

0 7

0 8

7 8 9 50

09		SYSTEM CODE W E		CAUSE CODE A		CAUSE SUBCODE A		COMPONENT CODE Z Z Z Z Z Z				COMP. SUBCODE Z		VALVE SUBCODE Z	
7	8	9	10	11	12	13	14	15	16	17	18	19	20		
LER RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.					
17		79		056		03		1		0					
21		22		23		24		25		26		27			
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.			
H		H		Z		Z		00000		N		N			
33		34		35		36		37		41		42			
PRINT COMP. SUPPLIER		COMPONENT MANUFACTURER													
Z		Z		9		9		9		9		9			
43		44		45		46		47		48		49			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 While RCIC was being operated in the steam condensing mode, per startup test. Procedure  
1 1 HNP-2-10371, the torus water level reached a level of 150.9 inches. Initiated torus  
1 2 drainage per HNP-2-1445 & had torus < 150" with in one hour. Instructed Operators to  
1 3 monitor torus level while testing of systems that have the potential of increasing the  
1 4 water level in the torus.

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

FACILITY STATUS (30) % POWER (29) OTHER STATUS (30) METHOD OF DISCOVERY (31) DISCOVERY DESCRIPTION (32)

1 5 C 23 0 0 2 29 NA B 31 Operator Observation

ACTIVITY CONTENT (33) RELEASED OF RELEASE (34) AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z 33 Z 34 NA NA

PERSONNEL EXPOSURES										
NUMBER			TYPE		DESCRIPTION					
1	7		0	0	0	(37)	Z	(28)	NA	
7	8	9	10	11	12	13				

PERSONNEL INJURIES																			
NUMBER				DESCRIPTION															
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
		0	0	0	40	NA													

LOSS OF OR DAMAGE TO FACILITY (43)  
TYPE DESCRIPTION NA 7907170096 S

PUBLICITY  
 ISSUED (45) DESCRIPTION (44) NA  
 2 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

NAME OF PREPARER S. X. Baxley - Supt. of Operations

PHONE: 912 367-7781