NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

# LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | PABVS1 (2) | 00-0000 | 0-00 (3) | 41111 (4) | (5)
LICENSEE CODE (9–14) | LICENSE NUMBER (15–25) | LICENSE TYPE (26–30) | CAT (57–58)

CON'T
01 | REPORT SOURCE L (6) | 05003344 (7) | 06 09 79 (8) | 07 08 79 (9)
DOCKET NUMBER (61–68) | EVENT DATE (69–74) | REPORT DATE (75–80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During an inspection of valve stem locking nuts on motor-operated valve operators,
03 the 1B LHSI Pump Suction Valve from the Refueling Water Storage Tank was found to be
04 inoperable.
05
06
07
08

09 | SYSTEM CODE SF (11) | CAUSE CODE E (12) | CAUSE SUBCODE B (13) | COMPONENT CODE CKTBRK (14) | COMP. SUBCODE E (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 79 | — | SEQUENTIAL REPORT NO. 017 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN C (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER L200 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The motor operator torque switch failed because of a broken torque switch roller and
11 roller pin. A new torque switch assembly was installed and the operator was
12 functionally checked by stroking the valve several times.
13
14

15 | FACILITY STATUS G (28) | % POWER 000 (29) | OTHER STATUS N/A (30) | METHOD OF DISCOVERY C (31) | DISCOVERY DESCRIPTION Special inspection (32)

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY N/A (35) | LOCATION OF RELEASE N/A (36)

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION N/A (39)

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION N/A (41)

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION N/A (43)

7907170 114 S

20 | PUBLICITY ISSUED N (44) | DESCRIPTION N/A (45)

337 066

NRC USE ONLY

NAME OF PREPARER J. A. Werling PHONE: 412-643-1258

GPO 917-928