

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
THE HARTFORD ELECTRIC LIGHT COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

P.O. BOX 270
HARTFORD, CONNECTICUT 06101
(203) 666-6911

May 30, 1979

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

ATTN: Mr. B. H. Grier, Director

Docket No. 50-423
AEC-MP3-184

Gentlemen:

SUBJECT: Millstone Unit No. 3
I.E. Bulletin No. 79-09

Reference (1): B. H. Grier letter to W. G. Council dated April 17, 1979.

Reference (1) transmitted the subject I.E. Bulletin to Northeast Nuclear Energy Company requesting appropriate action. The resulting investigation has shown that no General Electric Type AK-2 circuit breakers will be used in Millstone Unit No. 3 safety related systems.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

A handwritten signature in dark ink, appearing to read 'W. G. Council'. The signature is written in a cursive, flowing style with a horizontal line underneath.

W. G. Council
Vice President
Nuclear Engineering & Operations

cc: Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, D. C. 20555

334 247

7907190106