

TSC

# BALTIMORE GAS AND ELECTRIC COMPANY

GAS AND ELECTRIC BUILDING  
BALTIMORE, MARYLAND 21203

ARTHUR E. LUNDVALL, JR.  
VICE PRESIDENT  
SUPPLY

May 29, 1979

Office of Inspection and Enforcement, Region I  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

Attention: Mr. Boyce H. Grier, Director

Subject: Calvert Cliffs Nuclear Power Plant  
Units Nos. 1 & 2, Docket Nos. 50-317 & 50-318  
IE Bulletin - 79-03  
Longitudinal Weld Defects in ASME SA-312 type  
304 Stainless Steel Pipe Spools Manufactured by  
Youngstown Welding and Engineering Company

Gentlemen:

Please refer to our response dated April 16, 1979 on the subject bulletin in which we outlined a program for volumetric examination of longitudinal welds in the piping manufactured by Youngstown Welding and Engineering Company.

We have now reviewed the radiographs of the welds in accordance with the program outlined in our response. It was found during the review that the radiographs of some circumferential welds could not be interpreted for the entire specified length of longitudinal weld due to the interference of superimposed weld nomenclature data over the circumferential seam. Hence, we ultrasonically tested all specified longitudinal welds that could not be evaluated from the existing radiographs. The ultrasonic examination was conducted on one hundred percent of the longitudinal weld in a spool piece as opposed to the sampling technique outlined in our program. Consequently, our examination covered forty-five feet of longitudinal welds in piping located in the Unit No. 1 containment and in the Auxiliary Building of both Units out of a total of approximately forty-eight feet for both Units of Calvert Cliffs. The remaining three feet of piping are located in the Unit No. 2 containment, which could not be accessed since the unit is in operation.

366 065

②  
7907200481

May 29, 1979

We believe that this program of radiographic review as supplemented by ultrasonic examination provides good assurance of the quality and integrity of the piping welds addressed in IE Bulletin 79-03.

Very truly yours,

A handwritten signature in dark ink, appearing to read "Arthur L. Rundvold". The signature is fluid and cursive, with a long horizontal stroke at the end.

cc: J. A. Biddison, Esquire  
G. F. Trowbridge, Esquire  
E. L. Conner, Jr. - NRC  
J. W. Brothers - Bechtel  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555  
Attn: Director, Division of Reactor  
Construction Inspection

366 066