(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | A L J M F 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)

LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T

0 1 | REPORT SOURCE: L (6) | 0 5 0 0 0 3 4 8 (7) | 0 6 0 7 7 9 (8) | 0 7 1 9 7 9 (9)

DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 1020 on 6/7/79, radiation monitor R25A (Fuel Storage Pool Area, Gaseous Activity -

0 3 | Ventilation System Isolation) was declared inoperable due to pump failure. Tech. Spec

0 4 | section 3.3.3.1 and table 3.3.6 requires a minimum of two radiation monitor channels

0 5 | to be operable for the fuel storage area. Tech. Spec. 3.3.3.1 action statement

0 6 | requirements were met. R25A was returned to an operable status at 1020 on 6/15/79.

0 7 | The health and safety of the public were not affected.

0 8 |

0 9 | SYSTEM CODE: B B (11) | CAUSE CODE: E (12) | CAUSE SUBCODE: X (13) | COMPONENT CODE: P U M P X X (14) | COMP. SUBCODE: H (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 9 | — | SEQUENTIAL REPORT NO. 0 2 7 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN: A (32) | FUTURE ACTION: Z (33) | EFFECT ON PLANT: Z (34) | SHUTDOWN METHOD: Z (35) | HOURS (22): 0 0 0 0 | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORM SUB.: Y (24) | PRIME COMP. SUPPLIER: A (25) | COMPONENT MANUFACTURER: V 1 1 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | This event is attributable to pump malfunction. The pump was repaired, belts

1 1 | replaced and the temperature overload devices reset. Following repair and verification

1 2 | of proper operation, R25A was declared operable at 1020 on 6/15/79.

1 3 |

1 4 |

FACILITY STATUS: G (28) | % POWER: 0 0 0 (29) | OTHER STATUS (30): NA | METHOD OF DISCOVERY: A (31) | DISCOVERY DESCRIPTION (32): Operator observation

ACTIVITY RELEASED: Z (37) | RELEASE CONTENT: Z (38) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

PERSONNEL EXPOSURES: NUMBER 0 0 0 (39) | TYPE Z | DESCRIPTION: NA

PERSONNEL INJURIES: NUMBER 0 0 0 (40) | DESCRIPTION (41): NA

LOSS OF OR DAMAGE TO FACILITY (42): Z (43) NA

PUBLICITY: N (44) NA

NRC USE ONLY

POOR ORIGINAL

368 178

7907240 379

W. G. Hairston, III (205) 899-5156