NRC FORM 366
(7 77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | ARANO1 (2) | 00-000-00 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 1 3 (7) | 0 6 2 8 7 9 (8) | 0 7 2 7 7 9 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During Power operation, Reactor Building Hydrogen Purge
03 Fan, VSF-30A, tripped after 1 1/2 hours of a 10 hour
04 surveillance run, per procedure 1104.33. The
05 redundant fan was operable, so the public health
06 and safety was not affected. Other occurrence involving
07 the Hydrogen Purge fans were 50-313/79-001 and 77-018.
08 Reportable per T.S.6.12.3.2b.
09

SYSTEM CODE: S E (11) | CAUSE CODE: E (12) | CAUSE SUBCODE: X (13) | COMPONENT CODE: B L O W E R (14) | COMP SUBCODE: Z (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 9 — SEQUENTIAL REPORT NO 0 0 9 — OCCURRENCE CODE 0 3 — REPORT TYPE L — REVISION NO 0

ACTION TAKEN: E (18) | FUTURE ACTION: X (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0 0 0 0 | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORM SUB: N (24) | PRIME COMP SUPPLIER: A (25) | COMPONENT MANUFACTURER: N 0 1 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 It was determined that the Reactor Building Hydrogen
11 Purge Fan tripped on over current. The fan was
12 restarted using less sealing water, which resulted in
13 less current. The surveillance test was successfully completed.
14 Engineering is evaluating optimum seal water switch setting.

FACILITY STATUS: E (28) | % POWER: 0 4 0 (29) | OTHER STATUS (30): NA | METHOD OF DISCOVERY: B (31) | DISCOVERY DESCRIPTION (32): Surveillance Test

ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

PERSONNEL EXPOSURES — NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

PERSONNEL INJURIES — NUMBER: 0 0 0 (40) | DESCRIPTION (41): NA

LOSS OF OR DAMAGE TO FACILITY — TYPE: Z (42) | DESCRIPTION: NA

PUBLICITY — ISSUED: N (44) | DESCRIPTION (45): NA

NRC USE ONLY

NAME OF PREPARER Chris N. Shively PHONE 501/968-2519

435 026

7908020459