

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 AR A NO 2 00 - 00 00 - 00 00 4 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 58

CON'T
01 REPORT SOURCE L 0 5 0 0 0 3 6 8 0 6 2 7 7 9 0 7 2 7 7 9
7 8 9 DOCKET NUMBER 60 61 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in Mode 1 operation, the Condenser Vacuum pump
03 Radiation Monitors, 2RE0645 and 2RE0646, have been
04 inoperable for more than seven days. There has been
05 no primary to secondary leakage; therefore, the public
06 health and safety was not endangered. There have been no
07 similar occurrences. Reportable per E.T.S.
08 Monitoring requirement #4, in accordance with E.T.S.5.6.2b.
7 8 9

09 M C E E I N S T R U E Z
7 8 9 SYSTEM CODE 11 CAUSE CODE 12 CAUSE SUBCODE 13 COMPONENT CODE 14 COMP SUBCODE 15 VALVE SUBCODE 16

17 7 9 0 4 7 0 4 L 0
7 8 9 LER NO REPORT NUMBER 21 EVENT YEAR 22 SEQUENTIAL REPORT NO 23 OCCURRENCE CODE 24 REPORT TYPE 25 REVISION NO 26

18 19 Z 20 Z 21 0 0 0 0 N 23 N 24 A 25 X 9 9 9 9
7 8 9 ACTION TAKEN 33 FUTURE ACTION 34 EFFECT ON PLANT 35 SHUTDOWN METHOD 36 HOURS 37 ATTACHMENT SUBMITTED 38 NPRD-4 FORM 508 39 PRIME COMP SUPPLIER 40 COMPONENT MANUFACTURER 41

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The condenser vacuum pump discharge has been monitored by
11 grab samples or use of a portable Continuous Radiation Air Monitor (NMC),
12 as required by E.T.S.2.2.2 Gaseous Discharge Monitoring requirement
13 #3. Analysis indicates effluent remains at < MDA. The monitor malfunction
14 was caused by moisture buildup. An engineering evaluation is being conducted.
7 8 9

15 B 28 0 5 0 29 Pwr Escalation 30 A 31 NA
7 8 9 FACILITY STATUS 32 % POWER 33 OTHER STATUS 34 METHOD OF DISCOVERY 35 DISCOVERY DESCRIPTION 36

16 Z 33 Z 34 NA 35 NA 36 NA
7 8 9 ACTIVITY RELEASED 37 CONTENT 38 AMOUNT OF ACTIVITY 39 LOCATION OF RELEASE 40

17 0 0 0 37 Z 38 NA 39
7 8 9 PERSONNEL EXPOSURES 40 NUMBER 41 TYPE 42 DESCRIPTION 43

18 0 0 0 40 NA 41
7 8 9 PERSONNEL INJURIES 42 NUMBER 43 DESCRIPTION 44

19 Z 42 NA 43
7 8 9 LOSS OF OR DAMAGE TO FACILITY 44 TYPE 45 DESCRIPTION 46

20 N 44 NA 45
7 8 9 PUBLICITY 46 ISSUED 47 DESCRIPTION 48

NAME OF PREPARER Chris N. Shively PHONE 501/968-2519

NRC USE ONLY

7908020 492 S