

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

JUN 28 4 06:31

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

June 25, 1979

TELEPHONE AREA 704
373-4081

Mr. J. P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, GA 30303

Re: RII:JPO
50-369, 50-370
I.E. Bulletin 79-11

Dear Mr. O'Reilly:

In response to your letter of May 22, 1979, which transmitted I.E. Bulletin 79-11, a review of the safety related Class 1E systems was conducted at McGuire Nuclear Station. This review revealed that there are no Westinghouse type DB-75 or DB-50 circuit breakers in use at McGuire.

Very truly yours,


William O. Parker, Jr.

THH/sch

①
7908030601

440 082



790184
ORIGINAL COPY