

TIC

RECEIVED  
JUL 23 1979

**DUKE POWER COMPANY**

ELECTRIC CENTER, BOX 33189, CHARLOTTE, N. C. 28242

L. C. DAIL  
VICE PRESIDENT  
DESIGN ENGINEERING

July 19, 1979

Mr. J. P. O'Reilly, Director  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

RE: Catawba Nuclear Station  
IE Bulletin 79-11  
Duke Files: CN1412.11-1, EGS A-5.3

Dear Mr. O'Reilly:

In response to your letter of May 22, 1979, which transmitted Nuclear Regulatory Commission IE Bulletin 79-11, we wish to advise that a review of the designs of Catawba have been conducted. This review revealed that no Westinghouse DB-50 or DB-75 circuit breakers are used or planned for use in safety related systems at this station.

Very truly yours,



L. C. Dail, Vice-President  
Design Engineering

EKM/cam

421 134

79094

①  
OFFICIAL COPY  
7908060 005 Q