



Global Nuclear Fuel

Global Nuclear Fuel

Scott P. Murray
Manager, Facility Licensing

3901 Castle Hayne Road
P.O. Box 780
Wilmington, NC 28402
USA

T (910) 819-5950
scott.murray@ge.com

M190148

August 27, 2019

Attn: Document Control Desk
Director, Office of Nuclear Material Safety and Safeguards
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555-0001

Subject: GNF-A Semi-Annual Effluent Monitoring Report

References: 1) NRC License SNM-1097, Docket 70-1113
2) NRC Regulation 10CFR70.59

Dear Sir or Madam:

With respect to activities authorized by NRC License SNM-1097, the Global Nuclear Fuel-Americas, L.L.C. (GNF-A) facility in Wilmington, North Carolina hereby submits the semi-annual effluent monitoring report required by 10CFR70.59 for the time period of January through June 2019.

If you have any questions regarding this matter, please contact me at (910) 819-5950.

Sincerely,

A handwritten signature in black ink that reads 'Scott Murray'. The signature is fluid and cursive.

Scott Murray, Manager
Facility Licensing

Attachment: 1) Semi-Annual Effluent Monitoring Report (January- June 2019)

cc: NRC Region II Administrator, Atlanta, GA
T. Grice, USNRC, RII
T. Naquin, USNRC, NMSS
L. Cox, NCDHHS
M. Poirier, ANI
SPM 19-021

SEMI-ANNUAL EFFLUENT REPORT

Global Nuclear Fuel - Americas, LLC
Wilmington, North Carolina

January 2019 - June 2019

NRC License SNM 1097, Docket # 70-1113

Fiscal Weeks 1-26

I. GASEOUS EFFLUENT-PARTICULATE

NUCLIDES	QUANTITY (Ci)	CONCENTRATION (uCi/cc)	¹ APPENDIX B LIMIT (uCi/cc)	% of LIMIT	CEDE mrem	CDE (Lung) mrem
U234	7.14E-06	3.93E-15	5 E-12	0.08%	1.96E-02	1.65E-01
U235	2.97E-07	1.63E-16	6 E-12	0.00%	6.86E-04	5.71E-03
U236	2.29E-09	1.26E-18	6 E-12	0.00%	5.28E-06	4.40E-05
U238	9.93E-07	5.46E-16	6 E-12	0.01%	2.29E-03	1.91E-02
TOTAL	8.43E-06	---	---	---	2.26E-02	1.90E-01

EXHAUST VOLUME = 1.82E+15 (cc)

² Nuclide	QUANTITY (Ci)	CONCENTRATION (uCi/cc)	¹ APPENDIX B Limit (uCi/cc)	% of LIMIT	CEDE (mrem)
H-3	1.02E-05	1.38E-13	1E-05	0.00%	3.46E-07

EXHAUST VOLUME = 7.38E+13 (cc)

II. LIQUID EFFLUENT

NUCLIDES	QUANTITY (Ci)	CONCENTRATION (uCi/cc)	¹ APPENDIX B LIMIT (uCi/cc)	% of LIMIT	CEDE (mrem)	CDE (Lung) (mrem)	CDE (Bone Surface) (mrem)
U234	0.00E+00	0.00E+00	3 E-07	0.00%	0.00E+00	0.00E+00	0.00E+00
U235	0.00E+00	0.00E+00	3 E-07	0.00%	0.00E+00	0.00E+00	0.00E+00
U236	0.00E+00	0.00E+00	3 E-07	0.00%	0.00E+00	0.00E+00	0.00E+00
U238	0.00E+00	0.00E+00	3 E-07	0.00%	0.00E+00	0.00E+00	0.00E+00
TOTAL U	0.00E+00	---	---	---	0.00E+00	0.00E+00	0.00E+00

TOTAL VOLUME OF LIQUID EFFLUENT = 2.01E+08 (liters)

III. ABNORMAL RELEASES

	Air	Water	Total
# Releases	0	0	0
Activity Released (Ci)	0	0	0

IV. SUMMARY

	³ Max Release (uCi/cc)	CEDE, total (mrem)	CDE (Lung), total (mrem)
Value	3.93E-15	2.26E-02	1.90E-01
Limit	5.00E-12	25	25
% of Limit	0.08%	0.09%	0.76%

¹ Limit from 10 CFR 20 Appendix B, Table 2, Columns 1 and 2. Air limit adjusted to reflect NRC License SNM-1097, Section 1.3.9.

² This nuclide is included due to the installation and testing of a neutron generator licensed by the State of North Carolina.

³ From nuclide with release that is the largest percentage of its release limit.

Notes:

Air sampling is continuous. H-3 gaseous effluent is calculated. Water samples analyzed are representative, continuous composite samples of the process effluent stream.

Reported effluent concentration values are representative of the effluent concentration at the point of release and do not consider