



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

PRODUCTION DEPARTMENT

June 20, 1979

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, N. W. - Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Director

Dear Sir:

Grand Gulf Nuclear Station  
File 0260/15521/15525  
Interim Report No. 1 for PRD  
79/10 As Defined in 10 CFR 50.55(e)  
AECM-79/64

On May 21, 1979, Mississippi Power & Light Company notified Mr. D. S. Price of your office of a potentially reportable deficiency at the Grand Gulf Nuclear Station construction site. The deficiency concerns a problem with the gross failure output function of both the Master and Slave Trip Units of the Rosemount Model 510 DU Trip Calibration System. We have determined that this latter is reportable within the meaning of 10 CFR 50.55(e). Details of the latest findings are described in the attached interim report and we expect to submit a final report by November 16, 1979.

Yours truly,

L. F. Dale  
Nuclear Project Manager

415 347

JRF:pa  
Attachment

cc: Mr. T. B. Conner  
Mr. R. B. McGehee

Mr. John G. Davis, Director ← THIS COPY FOR  
Division of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

bcc: Dr. D. C. Gibbs  
Mr. A. Zaccaria  
Mr. J. N. Ward  
Mr. D.M. Lake  
Mr. R. L. Scott  
Mr. J. P. McGaughy  
Mr. W. L. Nail  
Mr. T. E. Reaves  
Mr. C. K. McCoy  
Mr. F. W. Jly  
Potential Reportable Deficiency  
File

③  
7907190523

Member Middle South Utilities System

B019  
S111