NRC FORM 366
(7 77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | A R A N 0 2 (7) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
0 1 | REPORT SOURCE L (6) | 0 5 0 0 0 3 6 8 (7) | 0 6 0 9 7 9 (8) | 0 6 2 7 7 9 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During Mode 3 operation, Emergency Feedwater flow control valves
0 3 from the electric driven EFW pump, 2P7A, to the "A" Steam
0 4 Generator, 2CV-1025-1 and 2CV-1038-1, failed to close from a
0 5 control room demand signal. The open position is required for EFAS; therefore,
0 6 the EFW flowpath would be uneffected in an emergency situation. The remainder
0 7 of the EFW valves were successfully tested from the control room. Occurrence
0 8 similar to 50-368/79-035, 78-028, & 78-009. Reportable per T.S.6.1.9.1(b).

0 9

SYSTEM CODE: W B (11) | CAUSE CODE: E (12) | CAUSE SUBCODE: B (13) | COMPONENT CODE: V A L V Ø P (14) | COMP SUBCODE: A (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER — EVENT YEAR: 7 9 | SEQUENTIAL REPORT NO: 0 4 3 | OCCURRENCE CODE: 0 3 | REPORT TYPE: L | REVISION NO: 0

ACTION TAKEN: B (18) | FUTURE ACTION: Z (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0 0 0 0 | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORM SUB: N (24) | PRIME COMP SUPPLIER: N (25) | COMPONENT MANUFACTURER: E 2 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Investigation revealed that 2CV-1038-1 would not operate due to
1 1 a loose wire on the handswitch. Valve 2CV-1025-1 required to be
1 2 filled and vented with oil. The valves were operable within
1 3 the 72 hours as required by Action Statement T.S.3.7.1.2.
1 4

FACILITY STATUS: B (28) | % POWER: 0 0 0 (29) | OTHER STATUS (30): NA | METHOD OF DISCOVERY: A (31) | DISCOVERY DESCRIPTION (32): NA

ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

PERSONNEL EXPOSURES — NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

PERSONNEL INJURIES — NUMBER: 0 0 0 (40) | DESCRIPTION (41): NA

309 065

LOSS OF OR DAMAGE TO FACILITY (42) — TYPE: Z (43) | DESCRIPTION: NA

PUBLICITY — ISSUED: N (44) | DESCRIPTION (45): NA

NRC USE ONLY

NAME OF PREPARER: Chris N. Shively — PHONE: 501/968-2519

7907090297