NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | FLTPS3 (2) | 00-000-00 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 05000 252 (7) | 05 15 79 (8) | 06 14 79 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During power operation, the 3B Intake Cooling Water (ICW) pump motor drew
03 low current when started, and there was no discharge header flow increase.
04 The 2 remaining ICW pumps were operable, but TS 3.4.5.a.1 requires 3
05 operable pumps. However, only 1 pump is necessary under hypothe
06 accident conditions (FSAR page 9.6-5), therefore, public health and
07 safety was not affected. The pump was inoperable for about 2.5 hrs.,
08 which is less than the 24 hrs. allowed by TS 3.4.5.b.2.

09 | SYSTEM CODE WG (11) | CAUSE CODE E (12) | CAUSE SUBCODE X (13) | COMPONENT CODE PUMPXX (14) | COMP. SUBCODE B (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 79 — SEQUENTIAL REPORT NO. 019 — OCCURRENCE CODE 03 — REPORT TYPE LL — REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP SUPPLIER A (25) | COMPONENT MANUFACTURER J105 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 A possible cause of the occurrence was debris at the pump suction bell.
11 The pump was backflushed, and then tested satisfactorily. After the
12 occurrence, divers found no significant debris at the pump. If there
13 is any further problem, it will be noted during the weekly ICW pump
14 rotation.

15 | FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

309 358

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

NAME OF PREPARER M. A. Schoppman PHONE: (305) 552-3802

7907090311