(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 GAEIH1 (2) 0000000000 (3) 41111 (4) (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

C T 01 REPORT SOURCE L (6) 05000321 (7) 061379 (8) 070279 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While performing Surveillance procedure HNP-1-3004. To functionally test Scram
03 Discharge Volume Hi-Level switches C11-N013A,B. The switches were found to be in-
04 operable. Reactor was in Refuel mode and redundant switches C11-N013C,D were operable,
05 There was no effect on public health or safety.
06
07
08

09 SYSTEM CODE IA (11) CAUSE CODE E (12) CAUSE SUBCODE B (13) COMPONENT CODE INSTRU (14) COMP. SUBCODE S (15) VALVE SUBCODE Z (16)

(17) LER RO REPORT NUMBER: EVENT YEAR 79 — SEQUENTIAL REPORT NO. 038 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN X (18) FUTURE ACTION X (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS (22) 0000 ATTACHMENT SUBMITTED N (23) NPRD-4 FORM SUB. Y (24) PRIME COMP. SUPPLIER N (25) COMPONENT MANUFACTURER M040 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Level switches C11-N013A,B were opened for inspection. The float was found to be
11 bent on both switches and binding against the side of the float chamber. The float
12 rods were straightened, the switches reassembled and functionally tested. The
13 vendor will be called to perform an inspection of the remaining switches and deter-
14 mine the cause of failure. A follow up report will be submitted as soon as possible.

FACILITY STATUS H (28) % POWER 000 (29) OTHER STATUS (30) N/A — METHOD OF DISCOVERY B (31) DISCOVERY DESCRIPTION (32) Surveillance

ACTIVITY RELEASED Z (33) CONTENT OF RELEASE Z (34) AMOUNT OF ACTIVITY (35) N/A — LOCATION OF RELEASE (36) N/A

PERSONNEL EXPOSURES NUMBER 000 (37) TYPE Z (38) DESCRIPTION (39) N/A

PERSONNEL INJURIES NUMBER 000 (40) DESCRIPTION (41) N/A

LOSS OF OR DAMAGE TO FACILITY (43) TYPE Z (42) DESCRIPTION N/A 309 239

PUBLICITY ISSUED N (44) DESCRIPTION (45) N/A — NRC USE ONLY

NAME OF PREPARER R. T. Nix, Supt. Maintenance PHONE 912-367-7781

7907090376