

**NORTHEAST UTILITIES**



THE CONNECTICUT LIGHT AND POWER COMPANY  
THE HARTFORD ELECTRIC LIGHT COMPANY  
WESTERN MASSACHUSETTS ELECTRIC COMPANY  
ALBANY WATER POWER COMPANY  
NORTHEAST UTILITIES SERVICE COMPANY  
NORTHEAST NUCLEAR ENERGY COMPANY

P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
(203) 666-6911

May 30, 1979

United States Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

ATTN: Mr. B. H. Grier, Director

Docket No. 50-423  
AEC-MP3-185

Gentlemen:

SUBJECT: Millstone Unit No. 3  
I.E. Bulletin No. 79-04

Reference (1): B. H. Grier letter to W. G. Council dated March 30, 1979.

Reference (1) transmitted the subject I.E. Bulletin to Northeast Nuclear Energy Company requesting appropriate action. The resulting investigation has shown that no swing type check valves manufactured by Velan Engineering Corporation will be used in Millstone Unit No. 3 safety related systems.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

A handwritten signature in cursive script, reading 'W. G. Council', written over a horizontal line.

W. G. Council  
Vice President  
Nuclear Engineering & Operations

cc: Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Division of Reactor Operations Inspection  
Washington, D. C. 20555

310 082

7907090

385

Q