

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'TREPORT
SOURCE

REPORT SOURCE

60 L 6 61 0 62 5 63 0 64 - 65 0 66 3 67 2 68 4 69 7 70 0 71 6 72 1 73 3 74 7 75 9 76 8 77 0 78 7 79 1 80 3 81 7 82 9 83 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal operator surveillance of the control panel, the operator noticed an

03 | unexplained shift in the 2-CAC-ATH-1259-2 monitor indicating drywell oxygen concentra-

0	4	tion.
---	---	-------

[05] (Technical Specifications 3.6.6.4, 6.9.1.9b)

05 | Page

7 8 9 10 11 12 13 14 15 16

0 9 S C E A I N S T R U S Z

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

(17)	LER/RO REPORT NUMBER	[EVENT YEAR 79]	[—]	SEQUENTIAL REPORT NO.	[045]	[✓]	OCCURRENCE CODE	[03]	REPORT TYPE	[L]	[—]	REVISION NO.	[0]
		21	22	23	24	26	27	28	29	30	31	32	
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	(22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER				
[B]	(19) [G] (19)	[Z] (20)	[Z] (21)	[0][0][0][0]		[N] (23)	[Y] (24)	[A] (25)	[B][1][3][5] (26)				
33	34	35	36	37	40	41	42	43	44	47			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | An inspection found that the range switch had corroded contacts. The switch was

11 replaced and the instrument was calibrated and returned to service. Maintenance

12 Instruction 10-3A will be revised to inspect/clean this switch monthly. This is

1 3 | considered an isolated event and no further action is required.

1	4	
---	---	--

FACILITY STATUS				% POWER			OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	28	0	7	5	29	NA	A	31	Operator Surveillance	

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z 33 Z 34 NA NA

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37) Z (38) NA				

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	8	0	0
0	0	0	40
		NA	

		LOSS OF OR DAMAGE TO FACILITY		
		TYPE	DESCRIPTION	
1	9	Z	(42) NA	(43)

7907160381

		PUBLICITY	(45)		NRC USE ONLY
ISSUED	DESCRIPTION	NA	196	152	
20	N(44)				

790716038/

NRC USE ONLY

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-9521