

Tic

Thomas J. Martin
Vice President
Engineering and Construction

Public Service Electric and Gas Company 80 Park Place Newark, N.J. 07101 201/430-8316

May 22, 1979

Mr. Boyce H. Grier, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

NRC IE BULLETIN NO. 79-04
INCORRECT WEIGHTS FOR SWING CHECK VALVES MANUFACTURED
BY VELAN ENGINEERING CORPORATION
NO. 1 AND 2 UNITS
HOPE CREEK GENERATING STATION

In reply to IE Bulletin No. 79-04 dated March 30, 1979, we
offer the following response:

Investigation into the subject bulletin affirms that no 3-inch,
4-inch, or 6-inch diameter swing check valves from Velan will
be used in Seismic Category I piping systems (or portions
thereof) on Hope Creek Generating Station.

Should additional information be desired, we will be pleased
to further discuss it with you.

Very truly yours,

T. J. Martin

517 156

7907180114