



Consumers
Power
Company

Stephen H. Howell
Senior Vice President

General Offices: 1945 West Cornwell Road, Jackson, Michigan 49201 • (517) 788-0453

July 20, 1979
Howe-205-79

Mr J G Keppler, Regional Director
Office of Inspection and Enforcement
US Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

MIDLAND NUCLEAR PLANT -
UNIT NO 1, DOCKET NO 50-329
UNIT NO 2, DOCKET NO 50-330
MAIN CONTROL PANEL, STATUS DISPLAY PANEL MODULES

Reference: S H Howell letter to J G Keppler; Midland Nuclear Plant;
Unit No 1, Docket No 50-329; Unit No 2, Docket No 50-330;
Main Control Panel, Status Display Panel Modules; Serial
Howe-173-79; dated June 20, 1979

The referenced letter was an interim 50.55(e) report on the status of
discrepancies found in soldered components of the J201 Main Control
Panel supplied by Magnetics. This letter is a final report in that the
part and process corrective actions have been determined and their
accomplishment scheduled as given in the attachment.

Stephen H. Howell

Attachment: MCAR-28, Final Report, dated July 20, 1979

CC: Director of Office of Inspection and Enforcement
Att: Mr Victor Stello, USNRC (15)

✓ Director of Office of Management
Information and Program Control, USNRC (1)

(4)

457 018
7907250325

Boia
5/11