

# NORTHEAST UTILITIES



100 L. B. Rte. 1, Hartford, Connecticut 06101  
Telephone: (203) 666-6911  
Telex: 203 666 6911  
FAX: (203) 666-6911

P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
(203) 666-6911

July 24, 1979

Docket No. 50-336

Director of Nuclear Reactor Regulation  
Attn: Mr. R. Reid, Chief  
Operating Reactors Branch #4  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

References: (1) V. Stello, Jr., letter to All PWR Licensees dated  
May 25, 1979.  
(2) W. G. Council letter to R. Reid dated June 18, 1979.

Gentlemen:

Millstone Nuclear Power Station, Unit No. 2  
Feedwater Lines

Pursuant to 10CFR50.54(f), the NRC Staff requested, (Reference (1)), information regarding the design, fabrication history, and inspection of feedwater lines at Millstone Unit No. 2.

In response to that request, Northeast Nuclear Energy Company (NNECO) docketed Reference (2), which addressed each of the Reference (1) concerns.

Subsequent review has determined that the response to Item 5 on Page 7, regarding fabrication history of the feedwater piping, should be revised as indicated below.

"A Charpy V-notch NDTT temperature of +20°F was specified for the 18" Schedule 60 pipe class EBB piping inside the containment penetration sleeves. The minimum absorbed energy was in accordance with N-421 of the ASME III Code."

464 310 P

(2)

7907310339

We trust you find this information satisfactory in response to Item 5 of Reference (1).

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

W. G. Council  
W. G. Council  
Vice President

By: W. F. Fee  
W. F. Fee  
Vice President

464 311