

## LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 AR AN 01 00 -0 00 00 -00 01 11 11 11 01 01  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21  
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 56

CON'T  
01 L 0 15 0 0 0 3 1 13 7 0 16 2 1 7 9 10 17 12 15 7 9  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29  
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10  
02 During Zero Power Physics Testing, Emergency Feed Actuation was received  
03 when the "A" OTSG startup level transmitter selection was shifted. The  
04 steam driven EFW pump, P7A, tripped on overspeed. Selection was shifted  
05 back and the pumps were stopped. P7A was manually started and overspeed  
06 tripped again. There have been no similar occurrences. This occurrence  
07 is reportable per T.S.6.12.3.2b

08 \_\_\_\_\_  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

09 WIB 11 D 12 Z 13 Z Z Z Z Z 14 Z 15 Z 16  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUPPLY VALVE SUBCODE

17 7 9 1 0 0 8 0 3 L 0  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
LEAK REF. NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION

18 E 19 G 20 Z 21 0 0 0 0 N 23 N 24 Z 25 Z 9 9 9  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPSD-4 FORM 504 PRINCIPAL COMP. SUPPLIER COR. EVENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27  
10 Investigation revealed overspeed trips were due to water in steam supply  
11 line. The steam traps upstream of the supply valves were isolated  
12 during the previous plant heatup. Traps were placed in service and  
13 EFW pump operability was proven. Procedures have been modified to  
14 include the traps in the valve lineup.

15 X 28 0 0 0 0 29 ZPP Testing A 31 NA 32  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

16 Z 33 Z 34 NA 35 NA 36  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

17 0 0 0 37 Z 38 NA 39  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

18 0 0 0 40 NA 41  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
PERSONNEL INJURIES NUMBER DESCRIPTION

19 Z 42 NA 43  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

20 NA 45  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
PUBICITY ISSUED DESCRIPTION

21 NA 46  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
NAME OF PREPARER Chris N. Shively PHONE 501/968-2519

NRC USE ONLY  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

7907310453 S