

## LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N E C P R 1 2 0 0 - 0 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5  
7 8 9 14 15 25 26 30 37 CAT 38

CON'T

0 1 REPORT SOURCE L 6 0 5 0 0 0 2 9 8 7 0 5 3 1 7 9 8 0 6 2 6 7 9 9  
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While performing surveillance test S.P. 6.3.5.5, RHR Pump 1A tripped during start on  
0 3 overcurrent in phase C. RTS 3.5. No significant occurrence took place. This event  
0 4 is not repetitive. It presented no adverse effects on public health and safety.  
0 5 Redundant systems were available.  
0 6  
0 7  
0 8

0 9 SYSTEM CODE C F 11 CAUSE CODE A 12 CAUSE SUBCODE C 13 COMPONENT CODE R E L A Y X 14 COMP. SUBCODE D 15 VALVE SUBCODE Z 16  
7 8 9 10 11 12 13 18 19 20  
17 LER/RO REPORT NUMBER 7 9 21 22 23 24 26 27 28 29 30 31 32  
ACTION TAKEN E 18 FUTURE ACTION H 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER C B B B 26  
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 A General Electric Model 12IAC66K8A overcurrent relay operating disc failed to return  
1 1 to its normal position. A small particle of debris was lodged between the disc and the  
1 2 magnet. This caused reduction in time delay for the relay contact to close. The relay  
1 3 was cleaned, recalibrated and retested. Correct operation of RHR Pump 1A was verified.  
1 4

1 5 FACILITY STATUS E 28 % POWER 0 8 1 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Operator Observation 32  
7 8 9 10 12 13 44 45 46 80

1 6 ACTIVITY CONTENT Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
7 8 9 10 11 44 45 80

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
7 8 9 10 11 12 13 80

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41  
7 8 9 10 11 12 80

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
7 8 9 10 11 12 80

2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45  
7 8 9 10 11 12 80

NAME OF PREPARER Ladislav F. Bednar

PHONE 402-825-3811

NRC USE ONLY