



435 Sixth Avenue
Pittsburgh, Pennsylvania
15219

(412) 456-8000

June 21, 1979

United States Nuclear
Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

Attention: Mr. Boyce H. Grier
Director

Gentlemen:

SUBJECT: Beaver Valley Power Station Unit No. 2
Docket No. 50-412
IE Bulletin 79-09
GE AK-2 Circuit Breakers


We have reviewed IE Bulletin 79-09 which was submitted with your letter dated April 17, 1979 and identifies potential problems with General Electric Type AK-2 Circuit Breakers.

Circuit Breakers of the type described in IE Bulletin 79-09 are not being used in any safety related system or other systems, and there are no plans to use them.

We have not received copies of the General Electric Service Advice Letters since, as described above, none of the subject circuit breakers were directly purchased for Beaver Valley Power Station Unit No. 2

DUQUESNE LIGHT COMPANY

By:


E. J. Woolever
Vice President

cc: Dr. E. Volgenau (15)
Mr. W. G. McDonald

7908030178

580 054