

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 C T M N S 2 0 0 - 0 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5
B 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

0 1 REPORT SOURCE L 6 0 5 0 0 0 3 3 6 7 0 6 2 7 7 9 8 0 1 7 2 7 7 9 9
B 69 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 At the completion of a surveillance test per T.S. 4.8.1.1.2.a.2, the output breaker
0 3 for the 12U Emergency Diesel Generator could not be opened remotely from the Control
0 4 Room; the breaker was manually tripped from the local station at the switchgear. Per
0 5 T.S. 3.8.1.1 action statement a, D/G 12U was declared inoperable and the remaining
0 6 AC sources were verified operable. The breaker is a G.E. Magna-blast, Model AM-4.16-
0 7 250-8 with a ML-13 Mechanism.

0 8
7 8 9
0 9
7 8
SYSTEM CODE 9 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP. SUBCODE 14 VALVE SUBCODE 15
E E 11 E 12 A 13 C K T B R K 14 A 15 Z 16
EVENT YEAR 21 22 SEQUENTIAL REPORT NO. 24 26 OCCURRENCE CODE 28 29 REPORT TYPE 30
7 9 0 1 9 0 3 L
17 LER/RO REPORT NUMBER 21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN 33 FUTURE ACTION 34 EFFECT ON PLANT 35 SHUTDOWN METHOD 36 HOURS 37 40 ATTACHMENT SUBMITTED 41 N 42 N 43 PRIME COMP. SUPPLIER 44 A 45 COMPONENT MANUFACTURER 46 G 0 8 0 47
B 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 A 25

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 A loose wire connection was found in series with the trip coil of the breaker. The
1 1 termination was tightened and the breaker was functionally tested satisfactorily. The
1 2 engine was started and its operability verified. The diesel was out of service
1 3 approximately 4 hours.

1 4
7 8 9
1 5 FACILITY STATUS 10 % POWER 11 12 OTHER STATUS 13 N/A 14 METHOD OF DISCOVERY 15 B 16 OPERATOR OBSERVATION 17
7 8 9 10 11 12 13 14 15 16 17
1 6 ACTIVITY CONTENT 18 19 AMOUNT OF ACTIVITY 20 N/A 21 LOCATION OF RELEASE 22
7 8 9 10 11 12 13 14 15 16 17
1 7 PERSONNEL EXPOSURES 18 19 NUMBER 20 21 TYPE 22 Z 23 DESCRIPTION 24 N/A 25
7 8 9 10 11 12 13 14 15 16 17
1 8 PERSONNEL INJURIES 19 20 NUMBER 21 22 DESCRIPTION 23 N/A 24
7 8 9 10 11 12 13 14 15 16 17
1 9 LOSS OF OR DAMAGE TO FACILITY 19 20 TYPE 21 DESCRIPTION 22 N/A 23
7 8 9 10 11 12 13 14 15 16 17
2 0 PUBLICITY 19 20 ISSUED 21 DESCRIPTION 22 N/A 23
7 8 9 10 11 12 13 14 15 16 17
7908030 300 481 201
NRC USE ONLY
203-447-1791