

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | G A E I H 2 | 2 | 0 0 0 0 0 0 0 0 0 0 0 0 | 3 | 4 1 1 1 1 | 4 | | | 5

7 8 9 | 14 | 15 | 25 | 26 | 30 | 35

LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T

REPORT SOURCE: 01 L 5 0 5 0 0 0 3 6 6 7 0 7 1 2 7 9 8 0 7 3 0 7 9 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | With the Reactor in the run mode, while performing procedure HNP-2-3409 (RCIC steam
0 3 | Line Pressure Instrument F T & C) the Inboard Steam Isolation Valve(2E51-F001) did
0 4 | not close when the isolation signal was given. The RCIC System was declared inop-
0 5 | erable and the Reactor brought to cold shutdown per Technical Specifications 3.7.3.A
0 6 | and 3.6.3.a.1. There were no effects to public health and safety.
0 7 |

SYSTEM CODE C E 11		CAUSE CODE E 12		CAUSE SUBCODE B 13		COMPONENT CODE V A L V E X 14				COMP. SUBCODE E 15		VALVE SUBCODE D 16	
LER RO REPORT NUMBER 7 8		EVENT YEAR 7 9		SEQUENTIAL REPORT NO. 0 6 9		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0			
ACTION TAKEN A 18		FUTURE ACTION X 19		EFFECT ON PLANT A 20		SHUTDOWN METHOD A 21		HOURS 0 0 3 4		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB Y 24	
PRIME COMP SUPPLIER N 25		COMPONENT MANUFACTURER P 3 0 5											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The valve stem had galled against the packing follower which prevented the valve
1 1 | from closing. The stem was replaced and procedure HNP-2-3409 was then performed
1 2 | satisfactorily. The vendor will be consulted for recommendations that should prevent
1 3 | a reoccurrence of this problem.
1 4 |

FACILITY STATUS: 1 5 B 20
 % POWER: 0 4 6 20
 OTHER STATUS: N/A 30
 METHOD OF DISCOVERY: 31
 DISCOVERY DESCRIPTION: Operator Observation 32

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 Z 37 N/A 38

2 8 9 10 11

AMOUNT OF ACTIVITY

N/A

LOCATION OF RELEASE

N/A 39

45 46

PERSONNEL EXPOSURES										
NUMBER				TYPE		DESCRIPTION				
1	7	0	0	37	Z	38	N/A			

PERSONNEL INJURIES		NUMBER	DESCRIPTION
1	2	0 0 0 41	N/A

LOSS OR GR. DAMAGE TO FACILITY (43)
TYPE DESCRIPTION
1 2 Z (42) N/A
7 8 9 10

PUBLICITY
 ISSUED DESCRIPTION (39)
 2 2 2 N 63
 7908060411
 N/A

7908060411

690134