

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 A L J M F 1 2 0 0 - 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

0 1 REPORT SOURCE L 6 0 5 0 0 0 3 4 8 7 0 7 1 7 7 9 3 0 8 0 3 7 9 9
7 8 60 61 DOC NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 At 1125 on 7-17-79, a control power fuse blew in the N31 source range drawer (fuse was
0 3 replaced with one from N41 power range drawer). At 1128 a second control power fuse
0 4 blew in the N31 drawer (fuse was replaced with one from N42 power range drawer). As a
0 5 result of removing the control power fuses from two out of four power range channels,
0 6 power was also removed from both source range channels. Tech Spec section 3.3.1.1 and
0 7 Table 3.3-1 requires a minimum of one source range channel to be operable in Mode 5.
0 8 N31 and N32 were returned to operation at approximately 1135 on 7-17-79. This
0 8 occurrence had no effect on the health and safety of the public.

SYSTEM CODE 1 3 (11)		CAUSE CODE A (12)		CAUSE SUBCODE C (13)		COMP. SUBCODE Z (15)		VALVE SUBCODE Z (16)	
EVENT YEAR 7 9 (17)		SEQUENTIAL REPORT NO. 0 3 1 (18)		OCCURRENCE CODE 0 3 (19)		REPORT TYPE L (20)		REVISION NO. 0 (21)	
ACTION TAKEN H (13)		FUTURE ACTION Z (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD Z (21)		HOURS 0 0 0 (22)	
ATTACHMENT SUBMITTED N (23)		NPRD-4 FORM SUB. N (24)		PRIME COMP. SUPPLIER Z (25)		COMPONENT MANUFACTURER Z 9 9 9 (26)		CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 This event is attributable to personnel error. The technician involved assumed

1 1 removal of fuses from N41 and N42 had no effect on N31 and N32 while in Mode 5. A

1 2 new fuse was placed in N42 approximately two minutes after loss of power to N32.

1 3 The individual involved has been re-instructed in the effects of power range control

1 4 power fuse removal on the source range channels.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	0	0	NA	A	Operator Observation			

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 2 33 10 34

AMOUNT OF ACTIVITY (35)

NA

LOCATION OF RELEASE (36)

NA

PERSONNEL EXPOSURES										
NUMBER			TYPE	DESCRIPTION						
1	7	0	0	0	(37)	2	(38)	NA		

PERSONNEL INJURIES		523 357	
NUMBER	DESCRIPTION		
00040	NA		

8 9		11 12		LOSS OF OR DAMAGE TO FACILITY		(43)	7908 070492
TYPE		DESCRIPTION					
1	9	7	42	NA			

PUBLICITY
ISSUED DESCRIPTION (45)

(2) (0) (N) (44) NA

NRC USE ONLY

8468 • J. Neurosci., July 26, 2006 • 26(30):8462–8470

W. G. Hairston, III

D4404E

(205) 899-5156