

USNRC REGION
ATLANTA SOUTH CAROLINA ELECTRIC & GAS COMPANY

POST OFFICE BOX 764

COLUMBIA, SOUTH CAROLINA 29218

E.H. CREWS, JR.
VICE-PRESIDENT AND GROUP EXECUTIVE
ENGINEERING AND CONSTRUCTION

JUL 5 9:56

June 29, 1979

Mr. James P. O. Reilly, Director
United States Nuclear Regulatory Commission
Region II, Suite 1217
230 Peachtree Street, N. W.
Atlanta, Georgia 30303

Subject: Virgil C. Summer Nuclear Station
Inspection & Enforcement Bulletin 79-11
Docket No. 50-395
Nuclear Engineering File 2.8950

Dear Mr. O'Reilly:

In response to NRC IE Bulletin 79-11, the lower reactor vessel head insulation and associated support system is supported from a frame supported from the vessel itself in the area around the nozzles. Large washer type fittings are provided around the guide tubes to allow for thermal expansion. The guide tubes are not used to support the insulation and associated support system.

If further information regarding this bulletin is required, please let us know.

Very truly yours,

E. H. Crews, Jr.

RBC:EHC:rh

cc: Office of Inspection & Enforcement
Washington, D. C.

790217

503 247
7908080099

OFFICIAL COPY