



Consumers  
Power  
Company

Stephen H. Howell  
Senior Vice President

General Offices: 1945 West Parnall Road, Jackson, Michigan 49201 • (517) 788-0453

June 21, 1979  
Howe 183-79

Mr J G Keppler, Regional Director  
Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, IL 60137

MIDLAND PROJECT  
DOCKET NO 50-329, 50-330  
IE BULLETIN 79-11  
FILE: 0505.12 SERIAL: 7187

We have reviewed IE Bulletin 79-11 on "Faulty Overcurrent Trip Device in Circuit Breaker for Engineered Safety Systems" against the Midland Plant design and have determined that Westinghouse Type DB50 or DB75 circuit breakers have not been used or are planned to be used in safety related systems at the Midland Plants Unit 1 and Unit 2.

SHH/jm

CC: Director, NRC Office of Inspection & Enforcement  
Director, Nuclear Reactor Regulation

593 350

JUL 2 1979

7908090297