

INDIANA & MICHIGAN POWER COMPANY

P. O. BOX 18
BOWLING GREEN STATION
NEW YORK, N. Y. 10004

June 1, 1979
AEP:NRC:00097

Donald J. Cook Nuclear Plant Unit No. 2
Docket No. 50-316
License Nos. DPR-74

Mr. James G. Keppler, Director
U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

- References: (1) NRC IE BULLETIN NOS. 78-12,
78-12A, 78-12B
ATYPICAL WELD MATERIAL IN
REACTOR PRESSURE VESSELS
- (2) "CHICAGO BRIDGE & IRON
COMPANY REPORT IN COMPLI-
ANCE WITH THE NRC BULLETINS
78-12 AND 78-12A", DATED
APRIL 24, 1979

Dear Mr. Keppler:

This letter and its attachments are in response to the above referenced I.E. Bulletins as they apply to Unit No. 2 of the D.C. Cook Nuclear Plant.

Chicago Bridge & Iron (CB&I), manufacturer of the reactor vessel for Unit 2, has submitted to the NRC, on April 24, 1979, a generic report (reference 2) providing the required weld material information on all reactor vessels fabricated by CB&I. Westinghouse and American Electric Power have reviewed the above referenced report and concluded that it represents adequately the data for the weldment material used in the reactor vessel of Unit No. 2 of the Donald C. Cook Nuclear Plant. Weldment material that might be used for verification purposes, is available in the archives of the Westinghouse Electric Corporation.

06 1979

7908090

1 595 002


Mr. James G. Keppler, Director

-2-

AEP:NRC:00097

As stated in our letter No. AEP:NRC:00097B dated May 21, 1979, the above information for Donald C. Cook Unit No. 1 reactor vessel will be submitted by July 2, 1979

Very truly yours


John E. Dolan
Vice President

JED:em

Attachments:

- 1) CB&I review certification letter to the NRC dated 4/24/79
- 2) CB&I letter to the NRC dated 4/24/79
- 3) Westinghouse letter to AEP dated 5/23/79

cc: R. C. Callen
G. Charnoff
D. V. Shaller-Bridgman
R. W. Jurgensen

595 003

ATTACHMENT I

Chicago Bridge & Iron Company

3700 Southwest North Houston Road
P.O. Box 40006
Houston, Texas 77010



Telephone 713, 463-7001

- 2 The documentation and information required by NRC Bulletins 78-12 and 78-12A, and Westinghouse PO #546-MVC-401945-MN for

CBI Contract # 68-3262

Vessel D. C. Cook II

are contained in the attached report.

Welding consumables were re-reviewed against the original requirements in accordance with the above listed documents. No deviations were found.

Based upon our records, I certify, to the best of my knowledge, this report is correct.

R E Kelley

Ralph E. Kelley
Manager, CGA Services

4-24-79

Date

595 004