



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

ILLUMINATING BLDG. ■ PUBLIC SQUARE ■ CLEVELAND, OHIO 44101 ■ TELEPHONE (216) 623-1550 ■ MAIL ADDRESS: P. O. BOX 5000

Dalwyn R. Davidson

VICE PRESIDENT

SYSTEM ENGINEERING AND CONSTRUCTION

*Serving The Best Location in the Nation*

July 11, 1979

Mr. James G. Keppler, Director  
Region III Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Re: Perry Nuclear Power Plant  
(Docket Nos. 50-440, 50-441)  
IE Bulletin No. 79-11

Dear Mr. Keppler:

The following has been prepared as a response to IE Bulletin 79-11, concerning the use of Westinghouse Type DB breakers.

There are no breakers of this type planned for use in safety related systems at the Perry Nuclear Power Plant.

In addition, the 480V overcurrent trip devices planned for this facility are solid state in lieu of electromechanical.

Very truly yours,

*Dalwyn R. Davidson*

Dalwyn R. Davidson

Vice President

System Engineering and Construction

DRD/cmw

cc: Mr. Victor Stello  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

531 348

JUL 16 1979

7908090591