


**LICENSEE EVENT REPORT**

CONTROL BLOCK: 

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	P	A	B	V	S	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	14						15	25										26	30					57	CAT	58		
		LICENSEE CODE							LICENSE NUMBER											LICENSE TYPE									

CON'T

REPORT SOURCE L 6 0 5 0 0 0 3 3 4 7 0 7 2 6 7 9 8 0 8 0 9 7 9 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | During testing of the Emergency Bus 4160V/480V General Electric Transformers, megger

03 | readings indicated a significant degradation of the insulation resistance as compared

04 | to the original acceptance testing.

05 \_\_\_\_\_

06 \_\_\_\_\_

07 \_\_\_\_\_

08 \_\_\_\_\_

7 8 9

SYSTEM CODE      CAUSE CODE      CAUSE SUBCODE      COMPONENT CODE      COMP. SUBCODE      VALVE SUBCODE

0 9      E B (11)      E (12)      A (13)      T R A N S F (14)      Z (15)      Z (16)

9 10      11      12      13      14      15      16

LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.	
[ 7   9 ]		[ 21   22 ]		[ 0   2   1 ]		[ 0   1 ]		[ T ]		[ 0 ]	
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED	
[ C   18 ]		[ Z   19 ]		[ Z   20 ]		[ Z   21 ]		[ 0   0   0   0 ]		[ N   23 ]	
[ 33   34 ]		[ 35   36 ]		[ 37   38 ]		[ 39   40 ]		[ 41   42 ]		[ 43   44 ]	
NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER							
[ Y   24 ]		[ A   25 ]		[ G   0   8   0 ]		[ 26 ]					
[ 45   46 ]		[ 47   48 ]		[ 49   50 ]		[ 51 ]					

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 All four transformers on the emergency buses have been replaced with properly

qualified ITE transformers which were available on-site to improve reliability.

1 2 |

1	3	
---	---	--

1	4	
---	---	--

FACILITY STATUS			% POWER			OTHER STATUS (30)			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION (32)		
1	5	G	28	0	0	0	29	N/A	C	31	Special test			

ACTIVITY CONTENT  
RELEASED OF RELEASE

1 6 2 33 34 N/A

AMOUNT OF ACTIVITY (35)

LOCATION OF RELEASE (36)

N/A

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	000	(37) Z (38)	N/A					

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	4	0	0	0	N/A

1		2		3		4		5		6		7		8		9		10		11		12	
TYPE				DESCRIPTION																			
1	9	7	42	N/A																7908140 828 S			

PUBLICITY		ISSUED		DESCRIPTION		NRC USE ONLY									
2	0	N	44	N/A		650 139									

NAME OF PREPARER J. A. Werling

PHONE: 412-643-1258