

TELEPHONE REPORT

Headquarters

AGENCY: Yellow Creek Unit 1

DOCKET #: 50-566

DATE: 8/3/79

TIME: 2:00 pm

LIC. (ICC) #: NCR - YC - 23

SUBJECT: Potential CDR - Unauthorized Bending of Reinforcing Steel

DESCRIPTION OF OCCURRENCE: Licensee reported that the bending of a length of
reinforcing steel in the Category 1 cable tunnel resulted in some
transverse cracking. The bending was done without proper engineering
approval. A 30-day report is due 9/4/79.

[Signature]
 SIGNATURE

POOR ORIGINAL

7908150567

[Handwritten marks]
 3019/10
 20080

656271