

IE RA

IE RA

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

PHILADELPHIA, PA. 19101

V. S. BOYER
VICE-PRESIDENT

(215) 841-4500

May 25, 1979

Mr. Boyce H. Grier, Director
Office of Inspection and Enforcement
Region I
United States Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUBJECT: Limerick Generating Station - Units 1 and 2
Docket Nos. 50-352 and 50-353
IE Bulletin 78-12
"Atypical Weld Material in Reactor Pressure Vessel Welds"
Reference: Letter dated September 29, 1978
from B. H. Grier to V. S. Boyer
File: GOVT 1-1 (IE Bulletin 78-12)

Dear Mr. Grier:

This letter is in complete response to IE Bulletins 78-12, 78-12A and 78-12B.

The Limerick Vessel supplier, CBI, has completed a search of records of low alloy, high tensile weld deposits used in all reactor pressure vessels built in their or their suppliers facilities. They have prepared a report of the results and have submitted the report to the NRC on April 24, 1979. The CBI report certified that there were no deviations found for the Limerick No. 1 and 2 reactor vessels.

Philadelphia Electric Company has archive weld deposit material from the Limerick vessels in storage, should verification tests be required.

It is our understanding from Mr. G. Wayne Reinmuth of the NRC that it is not necessary for PECO to submit a separate copy of the CBI report to the NRC.

Sincerely,

J. S. Boyer for V. S. Boyer

PAT/rm:10/8

Copy to: U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, DC 20555

298 322

7907060244

INTERIM REPORT

Accession No. 7907060245

Contract Program or Project Title:

Water Reactor Safety Research-- Heat Transfer Highlights - February 1979
Subject of this Document:

RSR Monthly Progress Report

Type of Document:

Technical Report

Author(s):

P. A. Lottes and others

Date of Document:

~~November 1978~~ Feb 1979

Responsible NRC Individual and NRC Office or Division:

Dr. Y. Y. Hsu, RES/RSR, Separate Effects Branch

This document was prepared primarily for preliminary or internal use. It has not received full review and approval. Since there may be substantive changes, this document should not be considered final.

NRC Research and Technical
Assistance Report

Prepared for
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

INTERIM REPORT

298 323